

*7-12' Paled
see 10,000 ft.*

APPLICATION

A 21333

R-test

SEWAGE DISPOSAL TESTING

P _____

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES

DISTRICT 5th

P. O. BOX 476, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 466-8000, EXT. 366

DATE April 1975

4 B.R. 1250 gal. septic tank

*4/18/75
9:30*
Drywell (and trench) to have 144 sq. ft. effective sidewall absorption area per bedroom to begin below the first 4 ft. of non porous soil. Maximum depth permitted for drywell or trench is 13 ft. below original grade. Place the drywell 2.25 ft. from the lot line that is 400 ft. long and 16.5 ft. from the lot line that is 362.58 ft. long. If trench is used in addition to drywell start trench at 6 foot earth

TO: THE COUNTY HEALTH OFFICER *buffer and place it parallel to the ground surface*
ELLICOTT CITY, MARYLAND. *contour the required distance.*

Note: Call for inspection of trench before gravel is installed
I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER COMMUNITY FINANCIAL SERVICES, INC.

ADDRESS _____ PHONE 730-8100

PROPERTY LOCATION:

SUBDIVISION CLARKSVILLE MEADOWS LOT NO. PARCEL "C" *(primary lot #)*

ROAD AND DESCRIPTION Intersection Rte 32 & Whitegate Lane

SIZE OF LOT 5.5 Acres TYPE BLDG. 4 Bedroom Residential

NUMBER OF BEDROOMS _____

IF NOT SINGLE RESIDENCE DESCRIBE _____

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE.

SIGNATURE OF APPLICANT W. Ronald Miller 593-3400

APPROVED BY Frank Skinner FOR Drywell (trench) DATE 6/2/75
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING Master's hold for certificate with back location

(BLDG. PERMIT SIGNED AND RETURNED 6/2/75)

THIS IS NOT A PERMIT

①
 0' Clay loam
 4' Sandy (red) loam
 6' micaceous (red) sandy loam
 7' sandy loam
 15'

②
 0' clayey (red)
 11' micaceous (red) sandy loam
 15'

③
 0' micaceous (red) sandy loam
 4' silty sand
 6' silty sand
 11'



INDICATE NORTH. - NAME ADJOINING ROADWAY AS BASE LINE.

Cross West Rd. (end)

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME	
			START	STOP	START	STOP		
4/25/75	1 high	5'	11:03	11:05	11:05	11:09	4 min	
	1A	13'	10:56	11:13	11:13	11:40	27 min	
	2	5'	11:37	11:38	11:38	11:40	2 min	
	2A	12 1/2'	11:39	11:49	11:49	12:15	26 min	
	3 low	5'	1:15	1:16	1:16	1:18	2 min	
	3A	13'	1:14	1:16	1:16	1:20	4 min	
	4	11 1/2'	visad clay to 5' sand below					

Depth 4' below grade in hole ①
 11 min by
 144 φ / B.R.

REMARKS Conf. all holes
 TYPE OF SOIL micaceous + sand loam below top 4-5' clay soil
 F.S. some boulders in high hole