

APPLICATION

A 13329

P _____

SEWAGE DISPOSAL TESTING

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

Septic Tank - 3 bedrooms - ¹⁰⁰⁰ ~~750~~ gal.
4 " " " " ¹⁰⁰⁰ gal.
1200

ELLICOTT CITY

DISTRICT 4DATE 1/24/68

pub. in room
Dry Well - 100 sq ft absorption sidewall area to begin below inlet pipe
inlet pipe at least 4 ft below original grade. Max depth permitted for Dry Well
below original grade is 13 ft.

*Place Dry Well within 125 ft or 165 ft from front lot line and about
55 ft from right sidewalk area when facing lot from Daisy Rd.*

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLANDI, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE
DISPOSAL SYSTEM.PROPERTY OWNER Robert G. JohnsenADDRESS Ashton, Maryland PHONE 1-924-4811

PROPERTY LOCATION:

SUBDIVISION Jennings Chapel Woods LOT NO. 1ROAD AND DESCRIPTION Daisy Road

OCCUPANT _____ PHONE _____

PERSON TO CONSTRUCT SYSTEM _____

ADDRESS _____ PHONE _____

SIZE OF LOT 44,122 sq. ft. TYPE BLDG. 3 or 4

NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE _____

SIGNATURE OF APPLICANT /s/ Robert G. JohnsenAPPROVED BY Dw. Moneyhan FOR Dry Well DATE 1-15-68

(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____

(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

