



Signed: [Signature] 7/24/10

FOGLE'S SEPTIC CLEAN, INC.

580 Obrecht Road
Sykesville, Maryland 21784
(410) 795-5670

Buyer:

FOGLE'S SEPTIC EVALUATION

4995 Centaurus Court

CLIENT Darlington INSPECTION ADDRESS MD 21036
CITY STATE ZIP PHONE

INSPECTION

Thurs 7/22 10:00 Jack Hill (Buyer)
DAY DATE TIME ORDERED BY
240-688-0844

WEATHER GENERAL GROUND CONDITIONS

System Age _____ ? Last Pumped 2009 ? Problems _____ ? (note below) Repair Date _____ ?
House Age 1977 ? Occupied yes ? Number _____ ? House Locked _____ ? (no entry)

- This is a subjective and visual inspection only, based upon many unknown and unseen factors.
- The condition of the Sewage Disposal System is reported as of the above date.
- **This report does not WARRANT nor GUARANTEE** continued functional Sewage Disposal System operations.
- If house has been unoccupied this report may not be accurate. Little or no use of the septic system could have allowed the problems to temporarily clear themselves.
- If a larger family is moving in than is presently occupying the house, the septic system may be subject to failure.
- If the general ground condition is wet, this report may not be accurate, as ground moisture may cover or hide actual septic effluent on the surface.
- In the above cases, it is strongly suggested that the septic system be recertified in 3 to 6 months.
- If system is rated below as marginal or unsatisfactory, it is suggested that the local health department be contacted to inspect and confirm the findings.

PAYMENT FOR THIS INSPECTION SIGNIFIES UNDERSTANDING AND ACCEPTANCE OF ABOVE CLAUSES.

The outside area showed no signs of septic system failure or as noted below:

Concrete septic tank is due for cleaning due to the amt of solids present. System has good flow from the house. Driveway has approx 2' of liquid depth remaining but should be pumped to remove some residue which has escaped the tank. Short drainfield has dry stone. Approx cost for pumping would be \$400.

with \$200
COD \$250.00 1011 7/22/10 [Signature]
Amount Check No. Date Paid Inspector Signature

CLIENT %

BILL TO COMPANY
ADDRESS CITY STATE

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 76147 Account #: 1930
Reference: Jack Hui Company: Fogle's Well Drilling
Location: 4995 Centaurus Ct. Requested By: Dave Fogle
Dayton, MD 21036 Source: Well Water
Date/ Time Collected: 7/22/2010 1000 Site: Kitchen Sink Tap
Date/Time Rec'd: 7/22/2010 1328 Treatment: None
Chlorine ppm: Free: ND Total: ND pH: 5.0
Collected By: K.Cassel 7238KC Well #: N/A

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	23.8	MPN/ 100 ml	<1.0	SM18 9223	7/23/2010 / 0830 / CCH
Bacteria, E. coli, MPN	1.0	MPN/ 100 ml	<1.0	SM18 9223	7/23/2010 / 0830 / CCH
Nitrate	11.7	mg/L	10	601	7/23/2010 / 1200 / CCH

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 4 ND = None Detected; N/A: Not Available
- 5 Sample collected by client, analyzed as received
- 6 pH & Chlorine level tested in lab

Reason for Test : Real Estate

Date Reported: 7/23/2010