

APPLICATION

A 16534

P _____

SEWAGE DISPOSAL TESTING

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY Septic Tank - 3 bedroom - 1000 gal 4' - 1250 gal. ELLICOTT CITY

DISTRICT 3

DATE 11/30/71

One Well - 100 sq. ft. absorbent sidewalk area per bedroom to begin below the first 3 ft. of non porous soil. Maximum depth permitted for dry well is 10 ft. below original grade. Locate dry well 30 ft. from left side line and 20 ft. from front property line as seen from Esthison Rd.

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Mark Wakefield, Jr.
12150 Mt. Albert Court
ADDRESS Ellicott City, Md., 21043 PHONE 531-5072

PROPERTY LOCATION:
SUBDIVISION Woodmark, Inc. LOT NO. 9, Block F, Sec. 9
ROAD AND DESCRIPTION Esthison
Carroll Mill Road

OCCUPANT _____ PHONE _____

PERSON TO CONSTRUCT SYSTEM _____
ADDRESS _____ PHONE _____

SIZE OF LOT 20'x125'x530'x270'x310' TYPE BLDG. 3 or 4
NUMBER OF BEDROOMS _____

IF NOT SINGLE RESIDENCE DESCRIBE _____

SIGNATURE OF APPLICANT Mark Wakefield, Jr.

APPROVED BY Robert V. Torre FOR One Well DATE 9/28/72
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

