

APPLICATION

A 28392

P _____

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

DISTRICT 5th

DATE 7/6/78

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES
P. O. BOX 476, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 465-5000, EXT. 356

*7/19/78
1:30 PM
No one seen
this date
C.D.R.
called office cancelled
per PHM*

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER (Bertram Ansell) seller
RICHARD D. LEONARD, JR. buyer

MAILING ADDRESS - P.O. BOX 58, BRINKLOW MD. 20727 PHONE 286-3124
RESIDENCE - LINDEN CHURCH RD., DAYTON

PROPERTY LOCATION:

SUBDIVISION BRIGHTON FARM ESTATES LOT NO. 2

ROAD AND DESCRIPTION directions NE CORNER OF BRIGHTON DAM RD. & NICHOLS DRIVE

SIZE OF LOT 3.054 Ac TYPE BLDG. NONE

NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE I PLAN TO BUILD A HOME (3 BEDROOMS)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE.

SIGNATURE OF APPLICANT Richard D Leonard Jr

APPROVED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

REJECTED BY Jim Stoyan FOR SEPTIC DATE 7/28/78
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING SOLID ROCK 4 to 5 FT. IN
THREE AREAS OF DIGGING

THIS IS NOT A PERMIT

7.28 #2

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE

oil Profile

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
7/28/98	No tests copy	/	/	/	/	/	
		/	/	/	/	/	
		/	/	/	/	/	
		/	/	/	/	/	
		/	/	/	/	/	
		/	/	/	/	/	
		/	/	/	/	/	
				Visual			

REMARKS COULD NOT TEST - SOLID ROCK 4'45'
TRIED 3 PERC HOLES

TYPE OF SOIL _____

TESTED BY JS

ALSO PRESENT: R. LEONARD JR.

HOWARD COUNTY HEALTH DEPARTMENT

JOYCE M. BOYD, M.D., M.P.H.
DEPUTY STATE AND
COUNTY HEALTH OFFICER



P.O. BOX 476
ELLCOTT CITY, MARYLAND 21043
TELEPHONE 992-2333

July 31, 1978

Mr. Richard D. Leonard, Jr.
P.O. Box 58
Brinklow, Md. 20727

Dear Mr. Leonard:

This is to inform you that the property owned by you and located in Brighton Farm Estates, Lot 2, Brighton Dam Road, failed to pass the standard percolation test on July 28, 1978. Therefore, this land is non-buildable until public sewer becomes available.


Very truly yours,

Donald W. Monaghan
Donald W. Monaghan,
Sanitarian


DWM:ds

BRIGHTON DAM ESTEES
 Lot # 2
 Not included

111 Has addition



Scale 1/2" = 100'



OWNERS
 T. GUY NICHOLS ESTATE
 & B. HENITT NICHOLS
 CLARKSVILLE, MD.

Rodney W. Miles
 9223 Snow Shoe Ln
 Columbia Md 21045

PREPARED BY:
 HAROLD W. MAGRUDER & ASSOC.
 ENGINEERS & SURVEYORS
 5 SHEPHERD ST., N. W.
 WASHINGTON 11, D. C.

APPROVED:

 Chairman
 Planning Comm.

 Director
 Planning Comm.

 Supervisor