Post-it® Fax Note 7671	Date 5-16	# of pages ▸ 3
To WAYNE FLACK	From Brian	
Co./Dept. N.V.	Co.	
Phone # Brantwood	Phone #	
Fax # 6,28,2	Fax #	

Approved Septic System Plan
Howard County Health Department

Signature Date

Total linear feet required 240 feet
Width of trench (es) 3.0 feet
Depth of trench (es) 4.0 feet
Depth of stone required below distribution pipe 2.0 feet

EXISTING EARTH DIKE TO BE REMOVED

EXISTING SILT FENCE REMOVED & REPLACED WITH SUPER SILT FENCE TO BE

Existing Non-Tidal Wetlands

* BSMT. DOES NOT SEWER BY GRAVITY

LOT 9

1250 GAL. SEPTIC TANK
INV. IN = 466
INV. OUT = 460.5
Private Septic Easement

DIST. BOX
Ex. GRD = 468
INV = 466

24' Access Easement

WYNTER HALL
Rev. El. C
FF = 477.00
G = 467.16

Gar.

EX. WELL

.25 Wetland

504.40'
N 33°25'14" E
S 33°25'14" W 796.89'
2.86 %

25' Private Access Easement for Lots 5 and 6

Reviewed for HOWARD S.C.D.
and meets Technical Requirements
Signature 6/26/00
U.S. Natural Resources Conservation Service
Date

THIS DEVELOPMENT P
FOR SOIL

WALTER W. & JANET
Liber 525
Zoned