

App. if possible
4/3/81
4/7/81

4/9/81 App'd JRS.

PERMIT

P 31194
A 24532

SEWAGE DISPOSAL SYSTEM
MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

05-381320

ELLICOTT CITY

DISTRICT 5th

INDEXED

DATE 2/20/81

Mitchell-Wiley

~~Robert L. Orndorff~~

IS PERMITTED TO INSTALL X ALTER

ADDRESS 13938 Highland Road, Clarksville, Md. 21029 PHONE 596-9394 465-6298

SUBDIVISION Flamewood ROAD 7536 Flamewood Drive LOT 9, Blk. D, Sec. 3

PROPERTY OWNER F. G. Marker, Inc.

**BUILDING PERMIT SIGNED
AND RETURNED**

ADDRESS 5900 Princess Garden Parkway, Lanham, Md. 20801

6/30/05 800154805-IG POOL

SPECIFICATIONS 4 bedrooms

SEPTIC TANK CAPACITY 1250 GALLONS

DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

DEEP TRENCH _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

SEEPAGE PITS _____ ABSORBENT SIDE-WALL AREA _____ SQ. FT.

INLET PIPE _____ FT. BELOW ORIGINAL GRADE, MAXIMUM DEPTH _____ FT. BELOW ORIGINAL GRADE

EFFECTIVE DEPTH AT _____ FT. BELOW ORIGINAL GRADE.

LOCATE DISPOSAL AREA _____ FT. FROM _____ LOT LINE AND _____ FT. FROM _____ LOT LINE AS SEEN WHEN

FACING LOT FROM

DRY WELL AND TRENCH - System to have 125 sq. ft. effective sidewall area per bedroom below inlet. Inlet at 4 ft. below original grade and maximum depth 10 ft. below original grade. Effective depth begins at 5 ft. below original grade. Locate the dry well 125 ft. from the right lot line and 95 ft. from Flamewood Drive, as seen when facing lot from Flamewood Drive. Total sidewall area in dry well to be 300 sq. ft. Trench to be 40 ft. long with a sidewall area of 200 sq. ft. Inlet at 4 1/2 ft., maximum depth 10 ft. and effective depth at 5 ft. below original grade. Come off left side of dry well, run trench toward left lot line. Follow contour to keep trench level.

PLANS APPROVED BY William W. Zepp and Frank A. Skinner DATE 1/10/78 & 11/17/80

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER.

NOTE: ALL PIPE FROM HOUSE TO DISPOSAL AREA MUST BE CAST IRON.

PERMIT VOID AFTER THREE YEARS.

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 8 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA ACCEPTED.

***INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT.**

**BUILDING PERMIT SIGNED
AND RETURNED**
5/28/02
800136400 1 1/2 story addition + deck
8/29/02 800138028 UG PROPANE TANK

A 24532