

9/5/69
Early a.m. 4:27 PM

PERMIT

34786

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

INDEXED

DISTRICT 5

DATE 9/5/69

Robert Dubin IS PERMITTED TO INSTALL ALTER 3

ADDRESS Rt. 2, Clarksville, Maryland PHONE 286-3432

A SEWAGE DISPOSAL SYSTEM LOCATED AT _____

SUBDIVISION Clarksville Ridge ROAD Crows Nest Road LOT 37

PROPERTY OWNER C. D. Auld 531-5943

ADDRESS _____

SPECIFICATIONS

DRAIN FIELD _____ DEPTH _____ FEET, BOTTOM AREA _____ SQ. FT.

SEEPAGE PITS _____ ABSORBENT SIDE-WALL AREA _____ SQ. FT.

SEPTIC TANK CAPACITY _____ GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 22% & TANK CAPACITY 80%.

OTHER REPAIR - Trench - 40 ft. long, 12 ft. deep, 18" wide with 10 ft. stone.

CALL FOR INSPECTION WHEN TRENCH IS EXCAVATED BEFORE ANY GRAVEL IS INSTALLED.

PLANS APPROVED BY Palmer F. Wine DATE 9/5/69

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTIFY THE HEALTH DEPARTMENT 48 HOURS BEFORE EXCAVATIONS ARE TO BE BACK FILLED.

11/10

