

C1 12138 SEQUENCE NO. (MDE USE ONLY)

STATE OF MARYLAND WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 45 DAYS AFTER WELL IS COMPLETED.

(THIS NUMBER IS TO BE PUNCHED IN COLS. 3-6 ON ALL CARDS)

COUNTY NUMBER 13

DATE RECEIVED MM DD YY 5 8 02

DATE WELL COMPLETED MM DD YY 5 8 02

DEPTH OF WELL 375 (TO NEAREST FOOT) PERMIT NO. FROM 'PERMIT TO DRILL WELL' NO. 94-3044

OWNER: IKO STREET OR RFD: FOX MEADOW LANE TOWN: WEST FRIENDSHIP MD. SUBDIVISION: FOX CREEK SECTION: LOT: 2

WELL LOG Not required for driven wells

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

Table with columns: DESCRIPTION, FEET (FROM, TO), check if water bearing. Includes handwritten entries: BROWN SHALE 0-16, BLUE SLATE 16-200, BLUE SLATE 200-375.

THIS WELL WAS DEEPEMED FROM 200' TO 375' AFTER IT WAS TEST PUMPED

GROUTING RECORD

WELL HAS BEEN GROUTED (Y) (N) TYPE OF GROUTING MATERIAL: CEMENT (CM), BENTONITE CLAY (BC). NO. OF BAGS: 11, NO. OF POUNDS: 1034.

CASING RECORD

MAIN CASING TYPE: ST (STEEL), Nominal diameter: 6, Total depth of main casing: 26.

OTHER CASING (if used) diameter and depth.

SCREEN RECORD

screen type or open hole: ST (STEEL), BR (BRASS), HO (OPEN HOLE).

NUMBER OF UNSUCCESSFUL WELLS: 0

WELL HYDROFRACTURED (Y) (N)

CIRCLE APPROPRIATE LETTER: A (ABANDONED), E (ELECTRIC LOG), P (TEST WELL CONVERTED).

I HEREBY CERTIFY THAT THIS WELL HAS BEEN CONSTRUCTED IN ACCORDANCE WITH COMAR 26.04.04 'WELL CONSTRUCTION'...

DRILLERS LIC. NO. 1 MWD 139, Robert Clome

LIC. NO. 1 MWD 536, Robert Clome Jr.

SITE SUPERVISOR (sign. of driller or journeyman responsible for sitework if different from permittee)

DEPTH (nearest ft.)

Table with columns: E, A, C, H, S, R, E, N and depth values: 25, 375.

GRAVEL PACK IF WELL DRILLED WAS FLOWING WELL INSERT F IN BOX 68

MDE USE ONLY (NOT TO BE FILLED IN BY DRILLER) T (E.R.O.S.) W Q

PUMPING TEST

HOURS PUMPED: 1, PUMPING RATE: 3 gal. per min., METHOD USED TO MEASURE PUMPING RATE: TIME.

PUMP INSTALLED

DRILLER INSTALLED PUMP (YES) (NO) TYPE OF PUMP INSTALLED: C (centrifugal), CAPACITY: 31-35 GALLONS PER MINUTE.

LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS BUILDING, SEPTIC TANKS, AND/OR LANDMARKS...



