

FOR 814 8/73
C 1 0164
 THIS REPORT IS TO BE FILED IN THE STATE OFFICE OF THE HEALTH DEPARTMENT, ANNAPOLIS, MD. 21401
 WELL COMPLETION REPORT

STATE OF MARYLAND
 HEALTH DEPARTMENT ADMINISTRATION
 STATE OFFICE OF THE HEALTH DEPARTMENT, ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

WELL NO. **20307**
 COUNTY **Chesapeake**

DATE RECEIVED **11/11/74**
 DATE WELL COMPLETED **11/11/74**
 DEPTH OF WELL **300** FEET
 WELL IDENTIFICATION NO. **11**

OWNER **Riggs Construction**
 STREET OR RFD **17534 New Hampshire** POST OFFICE **Chesapeake**

WELL LOG

STATE THE KIND OF FORMATION PENETRATED, COLOR, GRAIN, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION USE IF NECESSARY	FEET	
	FROM	TO
<i>Top soil</i>	0	12
<i>loamy</i>	12	37
<i>granite</i>	37	300

*41' case
 36' joint
 12' log cement
 OR CPS*

GENERAL RECORD

WELL HAS BEEN DRILLED WHERE APPROPRIATE CODES

TYPE OF WELL: C1 C2 C3

NO. OF SACS **12** SO. OF POUNDS **1200**

GALLONS OF WATER **70**

DEPTH OF DRIFT SEAL (TO DEAREST FOOT):
 FROM **0** FT. TO **36** FT.

TESTED IF FOOT INDICATED:

MAIN CASING TYPE: 37 41

NOMINAL DIAMETER TOP UNFINISHED OF MAIN CASING (INCHES): **6**

TOTAL DEPTH OF MAIN CASING (DEAREST FEET): **41**

OTHER CASING BY CODE: DIAMETER (INCH) DEPTH (FEET)

SEALING MATERIAL: OT NO

IF WELL DRILLED FOR A FLOWING WELL CHECK ONE

LOG SCOPE CASING: YES NO

LOG INDICATOR: YES NO

FINISHING TEST

WATER LEVEL (DEAREST FEET): **1.0**

DEPTH OF WATER: **1.0**

TYPE OF FINISHING TEST: A B C

TYPE OF FOOT INDICATED: 1 2 3

SEALING MATERIAL: A B C

LOG SCOPE CASING: YES NO

LOG INDICATOR: YES NO

CIRCLE APPROPRIATE CODES

A WELL WAS DRILLED AND SEALED UNDER THE WELL HAS COMPLETED

B ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME: **J. E. Estep**

TRAFFIC: **J. E. Estep**

SIGNATURE: **J. E. Estep**

WELL LOG

WELL NO. **20307**

DEPTH (DEAREST FEET): **300**

DIAMETER OF BOREHOLE (DEAREST INCH): **6**

CREVEL PASS: YES NO

IF WELL DRILLED FOR A FLOWING WELL CHECK ONE

LOG SCOPE CASING: YES NO

LOG INDICATOR: YES NO

HOUSE

17534

Chesapeake

Pa.