

6/25/01
10:00
6/29/01 - 5:15
7/3/01 12:00
11/20/01 Repair pm
4/18/02 AM

4/25/02 - 2:00 Pump test 5/1/02 10:30
05-361060

PERMIT

SEWAGE DISPOSAL SYSTEM

HOWARD COUNTY HEALTH DEPARTMENT

BUREAU OF ENVIRONMENTAL HEALTH

410-313-2640

INDEXED

P 514982-D

A 514982-D
REPAIR

ISSUE DATE 3/15/2001

APPROVAL DATE 5/1/02

~~Jack Fyock Septic Service~~ Fogles Septic Clean IS PERMITTED TO INSTALL ALTER

ADDRESS P.O. Box 89, Glenelg, MD 21737 PHONE 410-988-9270

SUBDIVISION _____ LOT NUMBER _____ ADDRESS 12045 Route 216

PROPERTY OWNER Mullinix 410-792-7739 PROPERTY OWNER'S ADDRESS _____

SEPTIC TANK CAPACITY 1000 GALLONS 1000 GAL PUMP PIT

PUMP CHAMBER CAPACITY _____ GALLONS

NUMBER OF BEDROOMS 3 P. 1 OF 2

SQUARE FEET PER BEDROOM 180

LINEAR FEET OF TRENCH REQUIRED 135

TRENCHES: Trenches to be 2 feet wide. Inlet 3-6 feet below original grade. Bottom maximum depth 7 feet below original grade. 4 feet of stone below distribution box.

LOCATION: _____

REPAIR - PURPOSE - Existing septic system has failed.
Call for inspection when ground is opened so sanitarian can recommend repair. 3/14/02

(2) 70' TRENCHES IN REAR YARD SQUARE TO HOUSE
STARTING 25' FROM HOLE (5), RUNNING TOWARD HOLE (4)

PLANS APPROVED _____ DATE _____

PERMIT VOID AFTER 2 YEARS

- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: TOP OF SEPTIC TANKS ARE TO BE NO DEEPER THAN 3.0 FEET BELOW FINISH GRADE
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS, 90° ELBOWS ARE NOT ACCEPTABLE
- NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, DRAINFIELDS) TO BE 100 FEET FROM ANY WATER WELL UNLESS OTHERWISE SPECIFICALLY AUTHORIZED
- NOTE: NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH UNLESS SPECIFICALLY AUTHORIZED
- NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 35/40 PVC OR ABS
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS
- NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES
- NOTE: IF PUMPED SEPTIC SYSTEM REQUIRED, (1) SEPTIC PUMP DETAIL TO BE PROVIDED BY INSTALLER PRIOR TO ISSUANCE OF SEPTIC PERMIT (2) PUMP PERFORMANCE TEST IS NECESSARY PRIOR TO HEALTH DEPARTMENT APPROVAL OF SEPTIC PERMIT

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM
PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT
CALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM

A 514982-D

JACK FYOCK SEPTIC 331 1238 P.01

JACK FYOCK SEPTIC SERVICE, INC.

SEPTIC PUMPING, INSTALLATION, AND REPAIRS

P.O. BOX 89 • GLENELG, MD 21737

PHONE (410) 986-9270 or (410) 531-2939

FAX: (410) 531-1256

November 7, 2001

Ho. Co. Health Dept.

To whom it may concern,

There is a septic permit issued to Jack Fyock
Septic to repair system at: 12045 Scaggsville Rd.

This letter is to inform you that my company will
not be performing the work here. It is to my understand
that the job is to be done by Fogies Septic. I have spoke
with them and they will be refunding me for the permit.

Thank you,
Jack Fyock Septic Service

ORIGINAL

Sanction Computer & Business Supply (410) 524-0828

FOGLE'S SEPTIC CLEAN, INC.

660 OBRECHT
SYKESVILLE, MD 21784
(410) 795-6670

FARMERS AND
MECHANICS NATIONAL BANK
FREDERICK, MD

65-26550

23110

11/13/01

PAY TO THE
ORDER OF

Septic Service

\$ 25.00

DOLLARS

MEMO

*Permit for
Mullinex 12048 Seagoville Rd.*

Kimberly J. [Signature]

⑆023110⑆ ⑆055000262⑆ 247 633⑆9⑆

SECURITY FEATURES INCLUDED. DETAILS ON BACK.

FOGLE'S SEPTIC CLEAN, INC.

23110

Attn: Mary Lou

FOGLE'S SEPTIC CLEAN, INC.

23110

\$ 25.00

11/13/01

Septic Service

**PAYMENT
RECORD**

Ed + Jenny Mullinex