



Bureau of Environmental Health

8930 Stanford Boulevard, Columbia, MD 21045

Main: 410-313-2640 | Fax: 410-313-2648

TDD 410-313-2323 | Toll Free 1-866-313-6300

www.hchealth.org

Facebook: www.facebook.com/hocohealth

Twitter: HowardCoHealthDep

Maura J. Rossman, M.D., Health Officer

September 18, 2013

Mary Jo Ambrose
6014 Old Lawyers Hill Road
Elkridge, MD 21075

RE: Variance Approval
6014 Old Lawyers Hill Road
Elkridge, MD 21075

Dear Ms. Ambrose:

The Department of Health has received your waiver request dated August 7, 2013 for the above referenced property. This agency will grant **approval** of the waiver to the required Percolation Certification Plan as required by the *Howard County Code, Subtitle 8, Section 3.805*. The waiver has been approved on the basis that the proposed work does not increase the number of bedrooms in the home and does not impact the area available for future on-site sewage disposal. Please be advised that any increase in the number of bedrooms will require the installation of best available technology for removal of nitrogen. Additionally, any future addition may require percolation testing and a Percolation Certification Plan will be required. Deviations from the site plan submitted with the request will be subject to further review by this Department.

Any questions regarding this decision may be directed to the Well and Septic Program of the Howard County Health Department.

Respectfully,

A handwritten signature in black ink, appearing to read 'Michael J. Davis', is written over a light grey rectangular background.

Michael J. Davis, R.S.

Assistant Director

Bureau of Environmental Health

MARY JO AMBROSE
6014 OLD LAWYERS HILL RD
ELKRIDGE, MARYLAND 21075

August 7, 2013

Jeffrey E. Williams
Howard County Health Department
Bureau of Environmental Health
Well and Septic Program
7178 Columbia Gateway Drive
Columbia, Maryland 21046

Dear Mr. Williams,

We are planning an addition to our home at
6014 Old Lawyers Hill Road in Elkridge, Permit
#B13002310.

With this correspondence we request a waiver on
the setback of the septic tank and all drain fields from
20 feet to 13 feet.

Also, we request the percolation certification test
and plan be waived due to the fact that no bedrooms
are being added to the home.

Thank you for your prompt attention to this
matter.

Sincerely,


Mary Jo Ambrose

Not
required →
for existing
condition.

9/18/13 →
Approved
M. Davis