

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
FILL IN THIS FORM COMPLETELY
COUNTY NUMBER **A 17384**

DATE RECEIVED (WRA USE ONLY) _____ DATE WELL COMPLETED **8/9/74** DEPTH OF WELL **112**
PERMIT NO. FROM "PERMIT TO DRILL WELL" **AC-73-0795**

OWNER **ENSLEY** DRILLERS IDENTIFICATION NO. **154**
STREET OR RFD **2409 SUNSET FARM Rd.** POST OFFICE **THOMAS ELLIOTT CITY, Md.**

WELL LOG
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING
DESCRIPTION FEET CHECK IF WATER BEARING
FROM TO

Fill dirt	0	2	
BROWN EARTH	2	7	
BROWN SHALE	7	23	
GRANITE ROCK	23	112	*

*8-14-74
27' case
25' grout
14' pipe
OR H.S.*

GROUTING RECORD
WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES NO
TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT BENTONITE CLAY
CEMENT NO. OF BAGS **14** NO. OF POUNDS **84**
GALLONS OF WATER **84**
DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM **0** FT. TO **23** FT.
CIRCUIT TYPES S1 STEEL C0 CONCRETE
 PL PLASTIC OT OTHER
MAIN CASING TYPE ST NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) **6** TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) **27**

CASING RECORD
OTHER CASING (IF USED) DIAMETER (INCH) _____ DEPTH (FEET) FROM _____ TO _____

SCREEN RECORD
SCREEN TYPE OR OPEN HOLE ST STEEL BR BRASS OR BRONZE HO OPEN HOLE
 PL PLASTIC OT OTHER

WELL LOG CONTINUED
1 2 3 (SEQ. NO.) 6 DEPTH (NEAREST WHOLE FOOT) FROM 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51
1 **112** 25 112 21
2
3

CIRCLE APPROPRIATE BOXES
 A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
 E ELECTRIC LOG OBTAINED
 P TEST WELL CONVERTED TO PRODUCTION WELL
I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.
DRILLERS NAME **WATER INCORPORATED**
SIGNATURE **J. Alan Swells**
WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) (I.R.O.S.) T W G
TELESCOPE CASING 70 LOG INDICATOR 72 OTHER DATA AVAILABLE 74 75 76

PUMPING TEST
HOURS PUMPED (TO NEAREST HOUR) **3**
PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) **15**
METHOD USED TO MEASURE PUMPING RATE **WATCH & RUN OFF**
WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING **32** (NEAREST FOOT)
WHEN PUMPING **100** (NEAREST FOOT)
TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST) A AIR P PISTON T TURBINE
 C CENTRIFUGAL R ROTARY O OTHER (DESCRIBE BELOW)
 J JET S SUBMERSIBLE
PUMP INSTALLED S
TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)
DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO
CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) **7**
PUMP HORSE POWER **1/3**
PUMP COLUMN LENGTH (NEAREST FOOT) **100**
CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT) + ABOVE } LAND SURFACE (NEAREST FOOT) **2**
 - BELOW }
LOCATION OF WELL ON LOT SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).
PITLESS ADAPTER