1230

TAYLES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401

WELL COMPLETION REPORT

COUNTY NUMBER A13312

DATE RECEIVED (WRA USE ONLY)

DATE WELL COMPLETED 11/13/79

DEPTH OF WELL 150 est (TO NEAREST FOOT)

PERMIT NO. FROM "PERMIT TO DRILL WELL" HO-79-2230

DRILLERS IDENTIFICATION NO. 209

OWNER STEWART, Jeff (LAST NAME, FIRST NAME)

STREET OR RFD 6066 C Town & Country POST OFFICE Ellicott City, Md. 21043

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION	FEET FROM	FEET TO	WATER BEARING
Mica Sand	0	27	
Mica Rock	27	150	X

WELL DESCRIPTION

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) Y N

TYPE OF GROUTING MATERIAL (CIRCLE ONE) CEMENT C M BENTONITE CLAY B C

NO. OF BAGS 18 NO. OF POUNDS 1720

GALLONS OF WATER 180

DEPTH OF GROUT SEAL (TO NEAREST FOOT)

FROM 0 FT. TO 27 FT.

(ENTER 0 IF FROM SURFACE)

CASING RECORD

CASING TYPE (INSERT APPROPRIATE CODE BELOW) S T STEEL C O CONCRETE P L PLASTIC O T OTHER

MAIN CASING TYPE S T NOMINAL DIAMETER TOP MAIN CASING (NEAREST INCH) 6 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 27

OTHER CASING (IF USED) DIAMETER (INCH) DEPTH (FEET) FROM TO

SCREEN RECORD

SCREEN TYPE OR OPEN HOLE (INSERT APPROPRIATE CODE BELOW) S T STEEL S R WIRE OR SLOTTED R N O OPEN HOLE P L PLASTIC O T OTHER

C 2

DEPTH (NEAREST WHOLE FOOT) FROM TO

1 R O 27 150

2

3

SLOTSIZE 1. ____ 2. ____ 3. ____

DIAMETER OF SCREEN ____ (NEAREST INCH)

GRAVEL PACK FROM TO

IF WELL DRILLED WAS A FLOWING WELL, CIRCLE BOX F

WRA USE ONLY (DO NOT TO BE FILLED IN BY DRILLER)

TELESCOPE CASING Y LOG INDICATOR TYPE OTHER DATA AVAILABLE

C 3

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) 6

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 1

METHOD USED TO MEASURE PUMPING RATE Time

WATER LEVEL (DISTANCE FROM LAND SURFACE)

DEPTH PUMPING 35 FEET

TIME PUMPING 140 (NEAREST FOOT)

TYPE OF PUMPER USED (CIRCLE APPROPRIATE BOX FOR PUMPING TEST)

A AIR M PISTON T TURBINE C CENTRIFUGAL R ROTARY O OTHER (SPECIFY DETAILS) J JET B SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (CIRCLE APPROPRIATE LETTER IN BOX — SEE ABOVE) A, C, J, P, R, S, T, O

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) Y N

CAPACITY:

GALLONS PER MINUTE (TO NEAREST GALLON)

PUMP HORSE POWER

PUMP COLUMN LENGTH (NEAREST FOOT)

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER DIMENSIONS)

+ ABOVE

− BELOW

LAND SURFACE 2 (NEAREST FOOT)

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE (SUCH AS BUILDING, SEPTIC TANK, AND/OR OTHER LAND MARKS) AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS) TO WELL.

N

CIRCLE APPROPRIATE BOXES

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME (PLEASE PRINT) Howard Dillon

SIGNATURE Howard Dillon

HEALTH