

DEPARTMENT OF WATER RESOURCES
STATE OFFICE BLDG., ANNAPOLIS, MARYLAND 21401

WELL COMPLETION REPORT

FILL IN THIS FORM COMPLETELY

THIS NUMBER SHOULD BE PUNCHED IN COLUMNS 2-6 ON ALL CARDS

COUNTY NUMBER 2462

DATE OF SAFETY

1-12-73

DEPTH OF WELL

250

PERMIT NO. FROM "PERMIT TO DRILL WELL"

40-123-00119

DATE WELL COMPLETED

(TO NEAREST FOOT)

DRILLER'S IDENTIFICATION NO.

120

OWNER Grivakis, Ernest

LAST NAME 617 Park Ave

FIRST NAME Baltimore

STREET OR RFD

POST OFFICE

WELL LOG

WELL DESCRIPTION

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE APPROPRIATE SHEETS)	FEET		CHECK IF WATER BEARING
	FROM	TO	
unburden	0	8	
loam shale	8	14	
red rock	14	250	X

GRouting RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES NO

TYPE OF GROUTING MATERIAL (CIRCLE BOX)

CEMENT BENTONITE CLAY OTHER

NO. OF BAGS 73 NO. OF POUNDS 1300

BALLONS OF WATER 78

DEPTH OF GROUT SEAL (TO NEAREST FOOT)

FROM 0 FT. TO 10 FT.

CASING RECORD

MAIN CASING TYPE S T

NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) 6

TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) 30

OTHER CASING (IF USED)

DIAMETER (INCH) _____ DEPTH (FEET) FROM _____ TO _____

SCREEN RECORD

SCREEN TYPE (CIRCLE APPROPRIATE BOX)

STEEL BRASS OR BRONZE OPEN HOLE PLASTIC OTHER

DEPTH (NEAREST WHOLE FOOT) 250

CIRCLE APPROPRIATE BOXES

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

B ELECTRIC LOG OBTAINED

C TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME Griffin Hara Sons Corp

TELESCOPE CASING LOG INDICATOR OTHER DATA AVAILABLE

PUMPING TEST

1 2 3 4 5 6 (REQ. NO.)

HOUR PUMPED (TO NEAREST HOUR) 6

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 1

METHOD USED TO MEASURE PUMPING RATE Submersible

WATER LEVEL: (DISTANCE FROM LAND SURFACE)

STATIC PUMPING 50 (NEAREST FOOT)

WELL PUMPING 240 (NEAREST FOOT)

TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST)

A AIR B PISTON Y TURBINE

C CENTRIFUGAL N ROTARY O OTHER (SEE BELOW)

J JET S SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER OR 'X' - SEE ABOVE: A, C, J, N, R, S, Y, O)

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO

CAPACITY:

GALLONS PER MINUTE (TO NEAREST GALLON) _____

PUMP HORSE POWER _____

PUMP COLUMN LENGTH (NEAREST FOOT) _____

CASING HEIGHT

(CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE } LAND SURFACE (NEAREST FOOT)

BELOW } _____

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

Pitless Adapter

HEALTH