

COPIED FROM ORIGINAL REC'D
BY LOT OWNER MR 2/14/02

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

WATER ANALYSIS REPORT

Laboratory ID #:	41960.1	Account #:	1142
Reference:	Jost	Company:	CASH ACCOUNT
Location:	3330 Rosemary Lane West Friendship, MD 21794	Requested By:	James Jost
Date/ Time Collected:	2/6/02 1111	Source:	Well
Date/Time Rec'd:	2/6/02 1251	Site:	R/O Tap
Chlorine ppm:	Free: ND Total: ND	Treatment:	Softner/Sed. Filter/Reverse Osmosis
Collected By:	J.Yeager 6176JY	pH:	6.5
		Well #:	No Tag

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD
Nitrate	2.31	mg/L	10	601

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
 - 2 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
 - 3 ND:None Detected
 - 4 Visual well check: Well in pit
- Reason for Test : Client's Information

Date Reported: 2/7/02

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

WATER ANALYSIS REPORT

Laboratory ID #: 41960 Account #: 1142
Reference: Jost Company: CASH ACCOUNT
Location: 3330 Rosemary Lane Requested By: James Jost
West Friendship, MD 21794 Source: Well
Date/ Time Collected: 2/6/02 1111 Site: Kitchen Tap
Date/Time Rec'd: 2/6/02 1251 Treatment: Softner/ RO Sediment Filter
Chlorine ppm: Free: ND Total: ND pH: 6.5
Collected By: J.Yeager 6176JY Well #: No Tag

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM 9223 B.
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM 9223 B.
Nitrate	7.33	mg/L	10	601

NOTES

- 1 mg/L = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 4 ND:None Detected
- 5 Visual well check: Well in pit
- 6 Sample collected prior to reverse osmosis

Reason for Test : Client's Information

Date Reported: 2/7/02