





A# 21066

**HOWARD COUNTY HEALTH DEPARTMENT**

*Joyce M. Boyd, M.D., County Health Officer*

February 19, 1991

Reply to:

Charles Streaker, Sanitarian  
461-9933 or 461-9934

Occupant  
8516 Blounts Lane  
Fulton, Maryland 20759

Re: Beaufort Park - Lot 2  
8516 Blount's Lane  
Well Permit No. HO-73-0877

Dear Occupant:

This is to advise you that the septic system was installed, inspected and approved on July 30, 1975.

The water sample recently submitted for testing was free of coliform and fecal coliform bacteria at the time of sampling and is bacteriologically safe for drinking.

**INTERIM CERTIFICATE OF POTABILITY**

This certifies that the initial sampling requirements of COMAR 26.04.04 "Well Regulations" have been met for the water supply system installed under permit(s) HO-73-0877. No guarantee can be given for health protection beyond this date of issue. Based upon a satisfactory investigation and evaluation by the Howard County Health Department, the Department of Health and Mental Hygiene accepts this well system as required by COMAR 26.04.04.09.

This certificate may become final upon completion of the final bacteriological test which is to be taken by the county health department within six months. The well owner accepts his responsibilities under COMAR 26.04.04.10.

December 14, 1975  
Date Well Approved

*NO<sub>3</sub> - 15.6*

*3-19-91, NO<sub>3</sub>-20.5*

January 9, 1991  
Date of Water Sample

*Charles Streaker*  
Approving Authority  
Charles Streaker, Sanitarian  
Water and Sewerage Program

CBS:cm

Bureau of Environmental Health  
3525 Ellicott Mills Drive Ellicott City, Maryland 21043-4544  
Director 461-9956 Water and Sewerage, Permits 461-9933 Community Environmental Health 461-9944  
Technical Services 461-9955

*F.C.O.P. never issued*