

APPLICATION

A 09296

SEWAGE DISPOSAL TESTING

P _____

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 5

DATE 10/27/64

INVALIDATED
SITE CONDITIONS WITH
NOT CONFORMING WITH
CUMULATIVE
66 ft. from the back lot line and 49 ft. and 110 ft. from the left side line as lot is seen when facing it from Blount's Lane.
* No Basement Fixtures

750 gal. for 3 bedrooms
Septic tank - 1,000 " " 4 " "
138 sq. ft. bottom area
Bottom of gravel to be
below original grade. The
excavation must be followed exactly.
The area between 25 ft. and
75 ft. from the back lot line and 49 ft. and 110
ft. from the left side line as lot is seen when
facing it from Blount's Lane.

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Anne K. Gray & Susie Kondrup

ADDRESS 5132 Loughboro Rd., Washington 16, D. C. PHONE 363-5335

PROPERTY LOCATION:

SUBDIVISION Beaufort Park LOT NO. 3, Blk. G

ROAD AND DESCRIPTION 8520 Blount's Lane

OCCUPANT _____ PHONE _____

PERSON TO CONSTRUCT SYSTEM _____

ADDRESS _____ PHONE _____

SIZE OF LOT 40,506 sq. ft. TYPE BLDG. test per bedroom
NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE _____

SIGNATURE OF APPLICANT /s/ Gray & Kondrup

APPROVED BY P.D. Fletcher FOR Underground DATE 10/28
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

