



INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE.

Final

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME
			START	STOP	START	STOP	
2/16/23	1	11 1/2 ft	2:51	3:08	3:08	3:31	23 min
	2	5 1/2 ft	2:52	3:12	3:12	3:39	27 min
	3	10 ft	3:03	3:10	3:10	3:33	13 min
	4	4 1/2 ft	2:55	3:00	3:00	3:09	9 min
	5	Same hole		11 ft			
	6	"	"	11 ft			
All holes appear to have same type soil. Appears sandy, but also red							

REMARKS \_\_\_\_\_

TYPE OF SOIL 1

TESTED BY R. Tonn ALSO PRESENT: \_\_\_\_\_

1120  
1280  
1100


SEE ATTACHED  
SCALE DRAWING

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE

	DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME	ELEVATION	
				START	STOP	START	STOP			
ALL SAND	8/13/75	1	12	1056	1201	1201	1106	5	SEE ATTACHED SCALE DRAWING	
		1A	4	1002	1104	1104	1106	2		
		2	4	1120	1156	Failed first inch				
		2A	10	UNDERGROUND WATER 9 1/2 FT						
		3	11	1156	1207	1207	1216	9		
		3A	3	1200	1203	1203	1207	4		
		4	2	106	111	111	118	7		
		4A	22	111	132	Failed first inch				
		5	12	148	152	152				
		5A	7	154	204	Failed first inch				
		6	12	224	231	231		10		
		6A	5	215	231	231		10		
		5B	5	255	315	Failed first inch				
	REMARKS		4B	58	302	302	306	4		
	TYPE OF SOIL		5C	7	331	404	Failed first inch			
		7	10	ALL SAND						
TESTED BY		R.H.		ALSO PRESENT: JUDGE OWNER						
								FURNISHING		