

4/14/03

4/15/03 2PM

PUB. SEWER STATUS VERIFIED BY _____

03-296784

ISSUE DATE: 4/4/03

P 518613

APPROVAL DATE: ~~4/14/03~~ 4/15/03

A REPAIR

PERMIT

ON-SITE SEWAGE DISPOSAL SYSTEM HOWARD COUNTY HEALTH DEPARTMENT BUREAU OF ENVIRONMENTAL HEALTH

C&C Utility Service IS PERMITTED TO INSTALL ALTER

ADDRESS: 7398 Gaither Road, Sykesville PHONE NUMBER: 443-677-0627

SUBDIVISION: Twin Pines LOT NUMBER: 1

ADDRESS: 3104 STILES WAY
3155 Route 32 PROPERTY OWNER: C. Harrison

SEPTIC TANK CAPACITY (GALLONS): N/A

PUMP CHAMBER CAPACITY (GALLONS): _____

NUMBER OF BEDROOMS: 4

SQUARE FEET PER BEDROOM: 180

LINEAR FEET OF TRENCH REQUIRED: 180

TRENCHES:	Trench to be 2.0 feet wide. Inlet 3.0 feet below original grade. Bottom maximum depth 7.0 feet below original grade. Effective area begins at 3.0 feet below original grade. 4.0 feet of stone below distribution pipe.
LOCATION:	Install two 90' long trenches in the area of the new SDA. Distribution box is to be placed in the highest useable area of the SDA. Maintain 9' edge to edge trench seperation.
PURPOSE:	Repair being done due to abandonment of existing drywells that are in the middle of the proposed street. Drywell in the street to utilize #2 stone to prevent future settling during abandonment procedure.

PLANS APPROVED: John A. Boris, Jr., R.S. DATE: 4/22/02

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

**NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS
RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM
PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT
CALL 410-313-2640 FOR INSPECTION OF SEPTIC SYSTEM**

P518613

