

WATER RESOURCES ADMINISTRATION
TARRANT STATE OFFICE BLDG., ANNAPOLIS, MD. 21403
WELL COMPLETION REPORT

FILL IN THIS FORM COMPLETELY

DEPT. NO. FROM "PERMIT TO DRILL WELLS"
110-73-0328
COUNTY NUMBER
120

DEPTH OF WELL
125
TO NEAREST FOOT

OWNER
Emory Nelson

STREET OR RFD
911 5th Street

POST OFFICE
Council Bluffs, Md

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION	DEPTH		WATER BEARING
	FROM	TO	
Overburden	0	8	
Brown Shale	8	52	
Gray rock	52	125	X

ANALYTICAL RECORD

WELL HAS BEEN ANALYZED (CIRCLE APPROPRIATE BOX)

TYPE OF GROUTING MATERIAL (CIRCLE NO.)
BC

NO. OF BAGS **20** NO. OF POUNDS **2000**

GALLONS OF WATER **120**

DEPTH OF GROUT SEAL (NEAREST FOOT)
FROM 0 TO 51

CASING RECORD

MAIN CASING TYPE **S 7**

INTERNAL DIAMETER TOP (NEAREST INCH) **6**

TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) **54**

OTHER CASING (IF USED)

DIAMETER (INCH) _____ DEPTH (FEET) _____

SCREEN RECORD

SCREEN TYPE (CIRCLE APPROPRIATE CODE BELOW)

BY **BR** **HO** **PL** **OF**

STEEL BRASS OR BRONZE PLASTIC OTHER

WELL LOCATION

DEPTH (NEAREST WHOLE FOOT)
110 **125**

DIAMETER OF SCREEN (NEAREST INCH)
FROM _____ TO _____

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) **4**

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) **10**

METHOD USED TO MEASURE PUMPING RATE **Submersible**

WATER LEVEL (DEPTH FROM LAND SURFACE) BEFORE PUMPING **32** (NEAREST FOOT)

WHEN PUMPING **42** (NEAREST FOOT)

TYPE OF PUMPS USED (CIRCLE APPROPRIATE BOX) (ONE PUMPED TEST)

A AIR **P** PISTON **T** TURBINE
C CENTRIFUGAL **R** ROTARY **O** OTHER (CHECK BELOW)
J JET **S** SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER OR SET ABOVE: A, C, J, P, R, S, T, O)

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX)
YES **NO**

CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) _____

PUMP HORSE POWER _____

PUMP COLUMN LENGTH (NEAREST FOOT) _____

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHTS)
X ABOVE **7** (NEAREST FOOT)
BELOW _____

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

Pileless Adapter

CIRCLE APPROPRIATE BOXES

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

ELECTRIC LOG OBTAINED

TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLER'S NAME
George Harr Sons Corp

SIGNATURE *George Harr*

8-24-75
52' open
15' logs cement
not filled, not capped RM
cap 10' by Council Bluffs?