

APPLICATION

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES
P. O. BOX 478, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 483-8000, EXT. 350

DISTRICT 4
DATE 12/27/73

Septic Tank - 1000 gal.

*Dry Well - 414 sq ft absorbent sidewall area to begin below
the first 4 ft of original grade. Max depth permitted for Dry Well
is 12 ft below original grade.*

*Place Dry Well 140 ft from front lot line and
83 ft from right side line as shown on plat of land
175 ft from front of lot.*

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER David T. King

ADDRESS 9720 Whiskey Bottom Road, Laurel, Md. PHONE 728-2000

PROPERTY LOCATION:

SUBDIVISION _____ LOT NO. (6)

ROAD AND DESCRIPTION Cox's Mill Road

SIZE OF LOT 2.821 acres TYPE BLDG. 1

IF NOT SINGLE RESIDENCE DESCRIBE _____
NUMBER OF BEDROOMS
(Single Only, Drily.)

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE.

SIGNATURE OF APPLICANT David T. King

APPROVED BY D. W. Monaghan FOR Dry well DATE 1/25/73
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING _____

THIS IS NOT A PERMIT

