

STATE OF MARYLAND
 WATER RESOURCES ADMINISTRATION
 TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
 WELL COMPLETION REPORT

C 1 9112
 (THIS NUMBER IS TO BE PUNCHED IN COLUMNS 3-8 ON ALL CARDS)

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
 FILL IN THIS FORM COMPLETELY
 COUNTY NUMBER

DATE RECEIVED (WRA USE ONLY) 11-11-75
 DATE WELL COMPLETED 11-11-75
 DEPTH OF WELL 160 (TO NEAREST FOOT)
 PERMIT NO. FROM "PERMIT TO DRILL WELL" 77-113-1188
 DRILLERS IDENTIFICATION NO. 472

OWNER *Castilla Blaker*
 STREET OR RFD *Rt # 2* POST OFFICE *Woodlawn Md.*

WELL LOG

STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING
	FROM	TO	
<i>Top Soil</i>	<i>0</i>	<i>3</i>	
<i>Shaly</i>	<i>3</i>	<i>70</i>	
<i>Brown Slate</i>	<i>70</i>	<i>100</i>	<input checked="" type="checkbox"/>
<i>Heavy Rock</i>	<i>100</i>	<i>160</i>	

GROUTING RECORD

WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES NO

TYPE OF GROUTING MATERIAL (CIRCLE BOX):
 CEMENT BENTONITE CLAY

NO. OF BAGS *15* NO. OF POUNDS *1500*

GALLONS OF WATER *70*

DEPTH OF GROUT SEAL (TO NEAREST FOOT)
 FROM *0* FT. TO *30* FT.

CASING RECORD

MAIN CASING TYPE STEEL CONCRETE
 PLASTIC OTHER

NOMINAL DIAMETER TOP (MAIN) CASING (NEAREST INCH) *6*
 TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) *74*

OTHER CASING (IF USED)

DIAMETER (INCH) FROM TO

SCREEN RECORD

SCREEN TYPE OR OPEN HOLE STEEL BRASS OPEN HOLE ON BRONZE
 PLASTIC OTHER

DEPTH (NEAREST WHOLE FOOT)

1 *80* FROM *82* TO *160*

2

3

SLOT SIZE 1, 2, 3

DIAMETER OF SCREEN 56 (NEAREST INCH) FROM TO

GRAVEL PACK

IF WELL DRILLED WAS A FLOWING WELL CIRCLE BOX

WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER) (E.R.O.S.)

TELESCOPE CASING LOG INDICATOR OTHER DATA AVAILABLE

PUMPING TEST

HOURS PUMPED (TO NEAREST HOUR) *2*

PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) *6*

METHOD USED TO MEASURE PUMPING RATE *bucket*

WATER LEVEL (DISTANCE FROM LAND SURFACE)
 BEFORE PUMPING *40* (NEAREST FOOT)
 WHEN PUMPING *166* (NEAREST FOOT)

TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST)
 CENTRIFUGAL ROTARY OTHER (DESCRIBE BELOW)
 JET SUBMERSIBLE

PUMP INSTALLED

TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE) A, C, J, P, R, S, T, O

DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO

CAPACITY:
 GALLONS PER MINUTE (TO NEAREST GALLON) *37* *41*

PUMP HORSE POWER *37* *41*

PUMP COLUMN LENGTH (NEAREST FOOT) *43* *47*

CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)

ABOVE LAND SURFACE (NEAREST FOOT) *50*

LOCATION OF WELL ON LOT

SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).

MDE 160 depth

CIRCLE APPROPRIATE BOXES

A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED

E ELECTRIC LOG OBTAINED

P TEST WELL CONVERTED TO PRODUCTION WELL

I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.

DRILLERS NAME *L.H. Porter*

SIGNATURE *L.H. Porter*

