

A # 01900

Charles W. Cannon

HOWARD COUNTY  
MARYLAND STATE DEPARTMENT OF HEALTH  
8 Church Road  
ELLCOTT CITY, MARYLAND  
WELL COMPLETION REPORT

Report must be submitted within 10 days after completion of the well.

This is to certify that the well which has been completed on the below property

has been constructed and disinfected in compliance with the regulations and specifications of the State Board of Health. HO-66-W-310

The following construction and performance characteristics were noted:

- 1. Type, diameter and length of casing 6 1/4" Pipe 45' H.
- 2. Total depth of well 155'
- 3. Type, diameter and length of strainer None. Size of screen openings \_\_\_\_\_
- 4. Method of sealing top and bottom of screen \_\_\_\_\_
- 5. Method of grouting Cement. Quantity, cement used 188 lbs. Gals. water 10
- 6. Standing water level (depth below ground surface when not pumping) 5.8' H.
- 7. Yield of well in gallons per minute 1; elevation of water surface when pumped at the designated rate. \_\_\_\_\_
- 8. Number of hours pump operated at stipulated rate during pumping test 1
- 9. Record of any other pumping performance None
- 10. Log of materials encountered during drilling 4' H. Clay, 41' H. Sand & gravel, 110' H. Micron Rock
- 11. Physical appearance of water at end of final pumping test Clear
- 12. Variation in vertical alignment (how much the well casing varies from a truly plumb line) throughout its depth 0
- 13. Disinfected by 1 ounces of Quart % Chlorine (Brand name Clorox)

Property Owner Charles W. Cannon Address Dayton, Ind.  
Location of property Greenwood Rd.

Health Department Number \_\_\_\_\_ Dept. of Water Resources Permit No. HO-66-W-310

Date: 10/1/66, 19\_\_\_\_. Ed. Brown # 288  
Signature of well Driller

INSTRUCTIONS: This form is to be completed in duplicate and certified by the well driller upon completion of each drilled well. One copy will be forwarded to the property owner by the Health Department along with the final approval of the well.

0-4' clay  
4-45' sand & gravel  
45-155' pipe rock