approved 4/3/84

Stayer

3/23/84

PERMIT

P 33637

A 19178

Final Septic Insp 3/21/84 - 1° Clock

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH*

HOWARD COUNTY
BUREAU OF ENVIRONMENTAL HEALTH
992-2330

INDEXED

ELLICOTT CITY

DISTRICT 4th

DATE 3/8/84

Final Sewage Insp 1:45 4/3/84

Joe Wyatt M.R. ROSENBERG, BUILDER 3/27/84 at site C.B.S. IS PERMITTED TO INSTALL X ALTER

ADDRESS Manassas, Virginia PHONE 703-369-5691

SUBDIVISION Glenwood Estates ROAD 14604 Mustang Path LOT 4, Sec. 1

PROPERTY OWNER ~~Mark D. Walter~~ David & Nancy Hinton

ADDRESS 14606 N. Brook Drive, Woodbridge, Virginia 22193 Work: 964-2900 Phone: 992-1966

IF GARBAGE GRINDER IS USED INCREASE SEPTIC TANK CAPACITY BY 60% AND ABSORPTION AREA BY 22%.

GARBAGE GRINDER? YES ____ NO X

SEPTIC TANK CAPACITY 1000 GALLONS NUMBER OF BEDROOMS 3

DRY WELL AND TRENCH - 168 sq. ft. per bedroom if trenches only used. Inlet at 4 ft. ~~MAX~~ below original grade. Maximum depth 10 feet below original grade. Effective area begins at 5½ ft. below original grade. Start the trench(es) 30 ft. from the left lot line and 130 ft. from the front lot line as seen when facing the lot from the road. Trench to run toward the left rear corner of lot. Follow contour to keep trench level. If dry well and trench is used need 250 sq. ft. total in dry well for absorption area and a 33 foot trench is required off dry well for total area of 150 sq. ft. in the trench. Leave 5 ft. earth buffer between trench and dry well. Inlet, effective depth and bottom maximum depth would be same on dry well and trench system as for trenches only system.

INDEXED

BLDG. PERMIT SIGNED AND RETURNED 4/13/92 Serial # 41968 - Pool

PLANS APPROVED BY William W. Zepp & Craig Williams DATE 6/1/77 & 2/29/84

COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

NOTE: IF TRENCH IS USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCH.

NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER. NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH.

NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS.

PERMIT VOID AFTER THREE YEARS.

BLDG. PERMIT SIGNED AND RETURNED 12/14/94 Serial # 57507

NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER CAST IRON, CONCRETE OR TERRA COTTA, OR PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET MANHOLE TO GRADE REQUIRED

Addition

A 19178

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

*CALL 992-2330 FOR INSPECTION OF SEPTIC SYSTEMS.

EH - 2-1082