

Preliminary 5/10

APPLICATION

A 20659

SEWAGE DISPOSAL TESTING
STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

HOWARD COUNTY HEALTH DEPARTMENT 1000 GALTANK 3BR DISTRICT 5th
ENVIRONMENTAL HEALTH SERVICES 1250 GALTANK 4BR DATE 9/9/74
P. O. BOX 476, ELLICOTT CITY, MARYLAND 21043
TELEPHONE: 465-5000, EXT. 356

DRY WELL 360 SP FT SIDEWALL AREA BELOW INLET 3 BR
480 SP FT SIDEWALL AREA BELOW INLET 4 BR
DRYWELL INLET TO BE 3 FT DEEP & BOTTOM OF DRYWELL
TO BE 10 FT DEEP
PLACE THE DRY WELL 125 FT FROM THE LOTLINE WHICH IS
497.9 FT LONG AND 200 FT FROM THE LOT LINE
WHICH IS 650 FT LONG

TO: THE COUNTY HEALTH OFFICER TRENCH APPROVED - CALL SANITARIAN
ELLICOTT CITY, MARYLAND HODGES IF TRENCH SYSTEM WANTED
I, HEREBY, APPLY FOR THE NECESSARY TEST, IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE
DISPOSAL SYSTEM.

PROPERTY OWNER Dorothy L. Jones et al Property (Ed. Williams)
ADDRESS _____ Any questions call John Gary,
PHONE 788-2618

PROPERTY LOCATION:
SUBDIVISION _____ LOT No. 2
ROAD AND DESCRIPTION Howard Road

SIZE OF LOT 2.70 acres TYPE BLDG. 3 or 4 bedrooms
NUMBER OF BEDROOMS _____
IF NOT SINGLE RESIDENCE DESCRIBE _____

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC
FACILITIES BECOME AVAILABLE. BLDG. PERMIT SIGNED
AND RETURNED 5/21/75

SIGNATURE OF APPLICANT /s/ John B. Gary

APPROVED BY Raymond Hodges FOR [Signature] DATE 3/4/75
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING 1/26/74 Permit OK
2/1/74 Signed Final Permit with Certificate
Holds Returned 3/4/75 - DM SAID OK FOR DITCH ON DRYWELL

THIS IS NOT A PERMIT

20659

	SURVEY OR #	HD #	
	2	181A	L
	3	252A	
	4	3 Visual	
	1	45-4A	
see attached plat for Certified hole locations (permit)			
			lot 2

2.7 ac.

INDICATE NORTH - NAME ADJOINING ROADWAY AS BASE LINE.
14054 Howard Rd.

cutting 4
m
Max Depth
4 FT
6/26

DATE	TEST NO.	DEPTH	PRE-WET		TEST - 1" DROP		TIME	
			START	STOP	START	STOP		
7/26/74	1	3	1178	1125	1129	1130	1	
	1A	13	1130	1134	1134	1141	7	
	2	12	1249	1252	1252	1256	4	
	2A	3 1/2	1248	1249	1249	1250	1	
	3	11	TOP 3 FT CLAY BOTTOM 8 FT SAND					
	4	3	1235	1238	1238	1250	10	
7/26/74	4A	12	1235	1237	1237	1240	3	

ALLSAMPL
LOW
LOW
HIGH
HIGH
USE FOR
DW.

REMARKS _____

TYPE OF SOIL _____

TESTED BY RH _____

ALSO PRESENT: RA 10/12

Lot 2