

SEQUENCE NO. 0491
DATE RECEIVED 8-15-73
DATE WELL COMPLETED 9-00

STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT

THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
FILL IN THIS FORM COMPLETELY
COUNTY NUMBER

PERMIT NO. FROM "PERMIT TO DRILL WELL" 40-73-0367
DRILLER IDENTIFICATION NO. 02
OWNER LAST NAME Thompson Park
FIRST NAME H 0917
STREET OR RFD
POST OFFICE

WELL LOG
STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING.
DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)

FEET	FROM	TO	CHANGES MARKS
0-9	0	9	Top soil
9-75	9	75	Sandy
75-305	75	305	Granite

20ft
18 days cement
L.P.

WELL DESCRIPTION

GROUTING RECORD
WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) YES NO
TYPE OF GROUTING MATERIAL (CIRCLE BOX) CEMENT BENTONITE CLAY
NO. OF BAGS 18 NO. OF POUNDS 1500
GALLONS OF WATER 10+
DEPTH OF GROUT SEAL (TO NEAREST FOOT) FROM 0 FT. TO 30+ FT.
CASING RECORD
CASING TYPE: INSERT APPROPRIATE CODE BELOW
STEEL CONCRETE
PLASTIC OTHER
MAIN CASING TYPE: S+
NOMINAL DIAMETER: 6
TOTAL DEPTH OF MAIN CASING: 83

PUMPING TEST
HOURS PUMPED (TO NEAREST HOUR) 2
PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) 24
METHOD USED TO MEASURE PUMPING RATE bucket
WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING 10
WHEN PUMPING 0:00
TYPE OF PUMPED USED (CIRCLE APPROPRIATE BOX) AIR PISTON TURBINE
CENTRIFUGAL ROTARY OTHER (DESCRIBE BELOW)
JET SUBMERSIBLE
PUMP INSTALLED
TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE: A, C, J, P, R, S, T, O)
DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO
CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) 31
PUMP HORSE POWER 37
PUMP COLUMN LENGTH (NEAREST FOOT) 43
CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)
ABOVE BELOW LAND SURFACE 2 (NEAREST FOOT)

CIRCLE APPROPRIATE BOXES
A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
E ELECTRIC LOG OBTAINED
P TEST WELL CONVERTED TO PRODUCTION WELL
I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.
DRILLER'S NAME
SIGNATURE

SCREEN RECORD
SCREEN TYPE (INSERT APPROPRIATE CODE BELOW) SY BR HO
STEEL BRASS OPEN HOLE
ON BRASS
PL OT
PLASTIC OTHER
DEPTH (NEAREST WHOLE FOOT) FROM TO
DIAMETER OF SCREEN 36 (NEAREST INCH) FROM TO
GRAVEL PACK
IF WELL DRILLED WAS A FLOWING WELL (CIRCLE BOX) YES NO
DWR USE ONLY (NOT TO BE FILLED IN BY DRILLER) (E.N.D.S.)
TELESCOPE CASING 70
LOG INDICATOR 72
OTHER DATA AVAILABLE 74 75 76

LOCATION OF WELL ON LOT
SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).
House
30'
to well
Red

#42