



APPROVED
WALK-THRU BUILDING PERMIT
 BP# B00155376 A# 39074
 APP. SAN PAY DATE: 8/8/05
 DESC. OF WORK: 18x44 Deck +
12x18 steel for lawn equipment

 DENOTES PERC FIELD PER PLAT *10730
 DENOTES REVISED PERC FIELD PER PLOT PLAN

HOUSE LOCATION DRAWING

FOUNDATION LOCATION: 12/20/04
 FINAL LOCATION: 06/07/05
 BOUNDARY SURVEY: _____

SCALE: 1"=100'
 DATE: 06/09/05
 DRAWN BY: VLJ
 CHECKED BY: MLP
 PROJECT No.: 61733

*7755 BROWN BRIDGE ROAD
 B.R.L. = BUILDING RESTRICTION LINE
 TOP OF FOUNDATION ELEV. = 476.1'

LOT 26
 WATERMAN ESTATES
 LOTS 20-26
 A RESUBDIVISION OF LOTS 2
 10-16 OF SECTION 1 & SECTION
 AS RECORDED ON PLAT
 NOS. 7307, 7401 & 7402.
 5TH ELECTION DISTRICT
 HOWARD COUNTY, MARYLAND
 PLAT *10730

FILE INQUIRY FORM

Property Address: 7755 Browns Bridge Rd.

6/29/05

During BP review KJB found out that the sewage
disposal area was not large enough for 3 full systems.
KJB/JAB used the hand auger to try & get
some more area, (for location see BP Plan) For the
proposed house a pre-treatment unit was required. (KJB)