

DNR 214 9/71
C 1 2959 SEQUENCE NO. (WRA USE ONLY)
STATE OF MARYLAND
WATER RESOURCES ADMINISTRATION
TAWES STATE OFFICE BLDG., ANNAPOLIS, MD. 21401
WELL COMPLETION REPORT
 THIS REPORT MUST BE SUBMITTED WITHIN 30 DAYS AFTER WELL COMPLETION
FILL IN THIS FORM COMPLETELY
 COUNTY NUMBER **20701**
 PERMIT NO. FROM "PERMIT TO DRILL WELL"
HC-73-0932
 28 26 30 31 32 33 34 35 36 37
 209
 DATE RECEIVED (WRA USE ONLY) **3/1/75** DEPTH OF WELL **125**
 DATE WELL COMPLETED **3/1/75** (TO NEAREST FOOT) 28
 OWNER **WENNERBERG FLOYD**
 LAST NAME **WENNERBERG** FIRST NAME **FLOYD**
 STREET OR RFD **4085 ROXBURY HILL RD** POST OFFICE **GLENWOOD 21738**
WELL LOG
 STATE THE KIND OF FORMATIONS PENETRATED, THEIR COLOR, DEPTH, THICKNESS AND IF WATER BEARING

DESCRIPTION (USE ADDITIONAL SHEETS IF NECESSARY)	FEET		CHECK IF WATER BEARING
	FROM	TO	
Clay	0	20	
HARD white Rock	20	50	
Oolitic Rock	50	125 X	

20' casing
 19 1/2' open
 10 legs C.
 OR RDM 2-26-75

GROUTING RECORD YES NO
 WELL HAS BEEN GROUTED (CIRCLE APPROPRIATE BOX) Y N
 TYPE OF GROUTING MATERIAL (CIRCLE BOX) AA 44
 CEMENT CA 45 46 BENTONITE CLAY BC 48 49
 NO. OF BAGS **10** NO. OF POUNDS **219**
 GALLONS OF WATER **100**
 DEPTH OF GROUT SEAL (TO NEAREST FOOT)
 FROM **0** FT. TO **30** FT.
 (ENTER 0 IF FROM SURFACE)
CASING RECORD
 MAIN CASING TYPE (CIRCLE APPROPRIATE CODE BELOW) ST STEEL CO CONCRETE
 PL PLASTIC OT OTHER
 NOMINAL DIAMETER TOP (NEAREST INCH) **6** TOTAL DEPTH OF MAIN CASING (NEAREST FOOT) **25**
 OTHER CASING (IF USED)
 DIAMETER (INCH) _____ DEPTH (FEET) FROM _____ TO _____
SCREEN RECORD
 SCREEN TYPE (CIRCLE APPROPRIATE CODE BELOW) ST STEEL BR BRASS OPEN HOLE
 PL PLASTIC OT OTHER
WELL LOG
 C 2
 1 2 3 (SEQ. NO.) 4
 DEPTH (NEAREST WHOLE FOOT) FROM TO
 1 **H 0** **25** **125**
 2
 3
 23 24 26 30 32 36
 38 39 41 43 47 51
 SLOT SIZE 1, 2, 3, _____
 DIAMETER OF SCREEN _____ (NEAREST INCH)
 FROM _____ TO _____
 GRAVEL PACK _____
 IF WELL DRILLED WAS A FLOWING WELL, CIRCLE BOX F
 WRA USE ONLY (NOT TO BE FILLED IN BY DRILLER)
 TELESCOPE CASING 70 LOG INDICATOR 72 OTHER DATA AVAILABLE 74 75 76
PUMPING TEST
 C 3
 1 2 3 (SEQ. NO.) 4
 HOURS PUMPED (TO NEAREST HOUR) **6**
 PUMPING RATE (GALLONS PER MINUTE TO NEAREST GALLON) **10**
 METHOD USED TO MEASURE PUMPING RATE **TIME**
 WATER LEVEL (DISTANCE FROM LAND SURFACE) BEFORE PUMPING **30** (NEAREST FOOT)
 WHEN PUMPING **100** (NEAREST FOOT)
 TYPE OF PUMP USED (CIRCLE APPROPRIATE BOX) (FOR PUMPING TEST)
 C CENTRIFUGAL R ROTARY O OTHER (DESCRIBE BELOW)
 J JET S SUBMERSIBLE
 P PISTON T TURBINE
PUMP INSTALLED
 TYPE OF PUMP (WRITE APPROPRIATE LETTER IN BOX - SEE ABOVE) A, C, J, P, R, S, T, O
 DRILLER WILL INSTALL PUMP (CIRCLE APPROPRIATE BOX) YES NO
 CAPACITY: GALLONS PER MINUTE (TO NEAREST GALLON) _____
 PUMP HORSE POWER _____
 PUMP COLUMN LENGTH (NEAREST FOOT) _____
CASING HEIGHT (CIRCLE APPROPRIATE BOX AND ENTER CASING HEIGHT)
 ABOVE LAND SURFACE
 BELOW **2** (NEAREST FOOT)
LOCATION OF WELL ON LOT
 SHOW PERMANENT STRUCTURE SUCH AS BUILDINGS, SEPTIC TANKS, AND/OR OTHER LAND MARKS AND INDICATE NOT LESS THAN TWO DISTANCES (MEASUREMENTS TO WELL).
 HOUSE
 FRONT

CIRCLE APPROPRIATE BOXES
 A WELL WAS ABANDONED AND SEALED WHEN THIS WELL WAS COMPLETED
 E ELECTRIC LOG OBTAINED
 P TEST WELL CONVERTED TO PRODUCTION WELL
 I HEREBY CERTIFY THAT I HAVE COMPLIED WITH ALL CONDITIONS STATED ON THE ABOVE-CAPTIONED "PERMIT TO DRILL WELL", AND THAT INFORMATION CONTAINED IN THIS REPORT IS TRUE, ACCURATE, AND COMPLETE TO THE BEST OF MY KNOWLEDGE, INFORMATION AND BELIEF.
 DRILLER'S NAME
 (PLEASE PRINT) **HOWARD DILLON**
 SIGNATURE **Howard Dillon**