

APPLICATION

SEWAGE DISPOSAL TESTING

STATE OF MARYLAND - DEPARTMENT OF HEALTH AND MENTAL HYGIENE

A 30707
P _____

HOWARD COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SERVICES
P.O. BOX 476 ELLICOTT, MARYLAND 21043
TELEPHONE: 992-2330

DISTRICT THIRD
DATE 6/2/80

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND

I HEREBY APPLY FOR THE NECESSARY TEST IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER DENNIS F. LIGHT & ELIZABETH LIGHT
(JOHN T. SHAW & CYNTHIA SHAW CONTRACT PURCHASERS)
ADDRESS 937 PALLADI Drive 21227 PHONE Home 242-2613
Work 544-7238

PROPERTY LOCATION

SUBDIVISION DENIS F. LIGHT LOT NO. 1
ROAD AND DESCRIPTION GAITHER ROAD NEAR FORSYTHE RD

SIZE OF LOT 5.171 Acres TYPE BLDG. HOME

THE SYSTEM INSTALLED UNDER THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC FACILITIES BECOME AVAILABLE.

I FULLY UNDERSTAND THE FEE CONNECTED WITH THE FILING OF THIS PERC TEST APPLICATION IS NON-REFUNDABLE UNDER ANY CIRCUMSTANCES

SIGNATURE OF APPLICANT John Thomas Shaw
APPROVED BY _____ FOR _____ DATE _____

REJECTED BY Stephen G Kiel FOR any system DATE 6-20-80

HOLD PENDING FURTHER TESTS _____ DATE _____

REASONS FOR REJECTION OR HOLDING Rock at 2' to 10' in various perc
Holes SK+JS 6-20-80 WATER ON LOWER FRONT OF
Lot PERWZ 9-76 and RH 3-78

THIS IS NOT A PERMIT

6/20/80
9:30 A.M.

