

3/22/90 ASAP

03-296385

PERMIT

P 45689

SEWAGE DISPOSAL SYSTEM

A REPAIR

MARYLAND STATE DEPARTMENT OF HEALTH DISTRICT _____

HOWARD COUNTY
BUREAU OF ENVIRONMENTAL HEALTH
461-9933

DATE 03/15/90

INDEXED

DATE SYSTEM APPROVED 3/22/90

INSPECTOR JBF

Freedom Sanitation Service MICHAEL WRIGHT IS PERMITTED TO INSTALL _____ ALTER X

ADDRESS 2808 Liberty Road, Eldersburg, Md 21784 PHONE _____

SUBDIVISION _____ ROAD 12612 Howard Lodge Road or _____

PROPERTY OWNER _____ Mr. Charles Smith

ADDRESS _____ 12612 Howard Lodge Road
Sykesville, Md. 21784

~~IF GARBAGE GRINDER IS USED IN THIS CASE SEPTIC TANK CAPACITY BY 50% AND ABSORPTION TRENCH BY 25%~~

GARBAGE GRINDER XXXXXX YES XXXXXXXXXXXX NO XXXXXXXXXX

SEPTIC TANK CAPACITY _____ GALLONS NUMBER OF BEDROOMS 3

REPAIR - CALL FOR INSPECTION WHEN GROUND IS OPENED SO SANITARIAN CAN RECOMMEND REPAIR.

375 SPT SIDEWALK AREA TRENCH
2 FT WIDE 12 FT DEEP 8 FT STONE INLET
4 FT BUN TRENCH OFF OLD DRY WELL PH

PLANS APPROVED BY _____ Craig Williams DATE 03/15/90

COVER NO WORK UNTIL INSPECTED AND APPROVED

NEITHER THE HOWARD COUNTY COUNCIL NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

- NOTE: CLEANOUT REQUIRED EVERY 70 FEET OF SEWER LINE AND/OR AT 90° SWEEPS IN LINES FROM HOUSE TO DRAIN FIELDS
- NOTE: ALL PARTS OF SEPTIC SYSTEMS (I.E. TANK, DISTRIBUTION BOX, TRENCHES) TO BE 100 FEET FROM WELL (UNLESS OTHERWISE SPECIFICALLY AUTHORIZED)
- NOTE: IF DEEP TRENCHES ARE USED CALL FOR INSPECTION BEFORE AND AFTER PLACING GRAVEL IN TRENCHES
- NOTE: NO DRY WELL SHALL EXCEED 15 FOOT IN DIAMETER NO ABSORPTION TRENCH TO EXCEED 100 FEET IN LENGTH.
- NOTE: ALL PIPE FROM HOUSE TO SEPTIC TANK MUST BE CAST IRON OR SCHEDULE 40 PVC OR ABS
- PERMIT VOID AFTER TWO YEARS
- NOTE: INSTALL STAND PIPE ON SEPTIC TANK AND DRY WELL. STAND PIPES MUST BE 6 INCHES IN DIAMETER. CAST IRON, CONCRETE OR TERRA COTTA OR PVC OR ABS ACCEPTED. IF TOP OF SEPTIC TANK IS DEEPER THAN 3 FEET, MANHOLE TO GRADE REQUIRED
- NOTE: DISTRIBUTION BOXES MUST HAVE BAFFLES

*INSTALLER IS RESPONSIBLE FOR OBTAINING FINAL APROVAL ON THIS PERMIT

*CALL 461-9933 FOR INSPECTION OF SEPTIC SYSTEMS.

45689

