

MARYLAND STATE DEPARTMENT OF HEALTH
HOWARD COUNTY 1000 Cal Tank

ELLICOTT CITY
DISTRICT 4
DATE 9/24/71

*Day Well 300 sq ft sidewall area
below the inlet with the inlet
no deeper than 4 FT below grade and
the bottom of the day well no deeper than
12 FT*

*Place the day well 20 FT from the cemetery
wall and 130 FT from the lot line which is
75 3.19 FT long with a bearing
of S 08° 15' 13" W*

TO: THE COUNTY HEALTH OFFICER
ELLICOTT CITY, MARYLAND
I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE
DISPOSAL SYSTEM.

PROPERTY OWNER Clarence E. Bassler - Raymond Wright
ADDRESS 1694 Daisy Road, Woodbine, Md., 21795 19th Street Rd. Glen Burnie, Md.
PHONE 482-1461
PROPERTY LOCATION 21061-7nd.
SUBDIVISION 761-625

ROAD AND DESCRIPTION Daisy Rd., 1st. on right off rd. 100 ft. on right side right beside road
LOT NO. 8

OCCUPANT _____ PHONE _____
PERSON TO CONSTRUCT SYSTEM Willie Hopkins
Jennings Chapel Rd.
ADDRESS Woodbine, Md. PHONE _____

SIZE OF LOT 3.5712 acres TYPE BLDG. 34 NUMBER OF BEDROOMS _____
IF NOT SINGLE RESIDENCE DESCRIBE Single Family Dwlg.

SIGNATURE OF APPLICANT Clarence E. Bassler

APPROVED BY Raymond Wright FOR 10/7/71 DATE 10/6/71
(KIND OF SYSTEM)

REJECTED BY _____ FOR _____ DATE _____
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS _____ DATE _____

REASON FOR REFUSAL OR HOLDING _____

THIS IS NOT A PERMIT

