

9/20/62

# PERMIT

*approved*  
9/10/62  
*sum*

P 05805

A 05512

SEWAGE DISPOSAL SYSTEM

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

ELLICOTT CITY

DISTRICT 5

**INDEXED**

**INDEXED** 9/19/62

Tattie & Levy IS PERMITTED TO INSTALL  ALTER

ADDRESS \_\_\_\_\_ PHONE \_\_\_\_\_

A SEWAGE DISPOSAL SYSTEM LOCATED AT \_\_\_\_\_

SUBDIVISION Holiday Hills ROAD 10817 Hunting Lane LOT 53, BKG. 5

PROPERTY OWNER Robert J. Marshall Christina Gort / Mille Wertheimer

ADDRESS \_\_\_\_\_

**SPECIFICATIONS**

DRAIN FIELD \_\_\_\_\_ DEPTH \_\_\_\_\_ FEET, BOTTOM AREA \_\_\_\_\_ SQ. FT.

SEEPAGE PITS  ABSORBENT SIDE-WALL AREA 300 SQ. FT. begin below inlet pipe.

SEPTIC TANK CAPACITY 750 GALLONS

FOR GARBAGE GRINDER, INCREASE DISPOSAL AREA 22% & TANK CAPACITY 50%.

OTHER Place the dry well about 82 feet from front lot line-Hunting Lane, and  
about 36 feet from right side as you face from Hunting Lane.

PLANS APPROVED BY D. W. Monaghan DATE 7/25/62

FILL SEPTIC TANK AND DISTRIBUTION BOX WITH WATER BEFORE CALLING FOR AN INSPECTION. COVER NO WORK UNTIL INSPECTED AND APPROVED.

NEITHER THE HOWARD COUNTY COMMISSIONERS NOR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM.

BLDG. PERMIT SIGNET  
AND RETURNED 11/24/91  
Serial # 40427 -  
1-Story Addition

AD55120

