

# APPLICATION

A 03102

SEWAGE DISPOSAL TESTING

P \_\_\_\_\_

MARYLAND STATE DEPARTMENT OF HEALTH

HOWARD COUNTY

For 3 bedrooms.

ELLICOTT CITY

DISTRICT 2

DATE 10/25/60

*OT  
13 sq. ft.  
under stairs  
below inlet  
for bedroom*

*one 9 ft dia by 12 ft deep dry  
well located 18 ft from Hurdle Rd.  
and 47 ft from Ocean of lot. Inlet pipe  
3 ft below original grade.  
750 gal septic tank.*

TO: THE COUNTY HEALTH OFFICER  
ELLICOTT CITY, MARYLAND

I, HEREBY, APPLY FOR THE NECESSARY TESTS IN ORDER TO CONSTRUCT (OR RECONSTRUCT) A SEWAGE DISPOSAL SYSTEM.

PROPERTY OWNER Edwards and Wilson

ADDRESS Ellicott City PHONE E. C. 2195

PROPERTY LOCATION:

SUBDIVISION Bonnie Acres LOT NO. 15 Sect 3

ROAD AND DESCRIPTION Bonnie Acres Dr.

OCCUPANT \_\_\_\_\_ PHONE \_\_\_\_\_

PERSON TO CONSTRUCT SYSTEM \_\_\_\_\_

ADDRESS \_\_\_\_\_ PHONE \_\_\_\_\_

SIZE OF LOT 20,117 sq. ft. TYPE BLDG. test per bedroom  
NUMBER OF BEDROOMS

IF NOT SINGLE RESIDENCE DESCRIBE \_\_\_\_\_

SIGNATURE OF APPLICANT Richard Wilson

APPROVED BY J. Hennigan FOR Dry Well DATE 10-25-60  
(KIND OF SYSTEM)

REJECTED BY \_\_\_\_\_ FOR \_\_\_\_\_ DATE \_\_\_\_\_  
(KIND OF SYSTEM)

HOLD PENDING FURTHER TESTS \_\_\_\_\_ DATE \_\_\_\_\_

REASONS FOR REJECTION OR HOLDING \_\_\_\_\_

## THIS IS NOT A PERMIT

