AVP

2049

Rdbrn hvy L w/ clay skins 2'

Loam mica ~15%

EAST WK org L Loam

13'

2047/2046

Str rd brn hvy L

5

brn micac Loam/SL

BOTTOM 14'

2045

hvy L 5½'

lt brn brn L

12' Bottom



DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2nd INCH	P/F/H
4-24-06	2049	5'	3:10	3:18	Stopped due to time	≈8-10 min	P
	2047	5½	3:16	3:20	3:26	6	P
	2046	5½	3:18	3:22	3:29	7	P
	2045	NOT DUG DUE TO TIME					OK
	EXISTING SEPTIC APPEARS TO BE						
		BACKING UP. C/O on? Sub baffle.					
				S. Tank? owner says S. TANK, E House			
				to be raised			
	AREA HOMOGENEOUS						

REMARKS Holes dug on stake

SANITARIAN Kacu BACKHOE Hatfields OTHERS

TEST HOLES USED IN SDA AVG. PERC TIME SQ.-FT/BR

TRENCH WIDTH INLET DEPTH MAX. BOT DEPTH EFFECTIVE S/W


SOLID WASTE LANE
DEE'S GARDENS
STOP SIGN
10' TREE MAINTENANCE EASEMENT
50' B.R.L.
B
47,926 SF.
SPEED LIMIT SIGN
EX. DWELLING To Be Razed
10' TREE MAINTENANCE EASEMENT
Ex. Well To Be Abandoned
Ex. Greenhouses To Be Razed
PROPOSED 8'x10' ASPHALT SCHOOL BUS PAD
EX. SEPTIC To Be Abandoned
TREES TO BE REMOVED
PROP. BOLLARDS
1-1
49,870 SF.
1
40,294
Approved SP-07-04 8/16/08
296.57'
12' SWM ACCESS
20'x30' TURN AROUND
FOREBAY
D2
PUBLIC S.W.M., DRAINAGE & UTILITY EASEMENT
B-1
B-2
B-3
B-13
15' NO WOODY ZONE
CONCRETE WEIR STRUCTURE
BMP-2
POCKET POND FACILITY (P-5)
OWNED BY H.O.A. & JOINTLY MAINTAINED BY H.O.A. & HO. CO.
WITH PROPOSED IMPERVIOUS LINER
OWNED: H.O.A.
EASEMENT HOLDER: HOWARD