

Facsimile Cover Sheet

To: Howard Co. Health Dept.

Company:

Phone:

Fax: 410-313-2648

From: Ellen Mellott

Company: Fredericktowne Labs

Phone: (301) 293-3340

Fax: (301) 293-2366

Date: 02/24/15

**Pages including this
cover page:** 3

Enclosed is the water test report for the U&O permit for JKC Quality Construction, 17197 Hardy Road, Mt. Airy, MD
Thanks.



Fredericktowne Labs Inc.

ENVIRONMENTAL TESTING

3020 Venetia Court • P.O. BOX 245 • Myererville, MD 21773 • 800-332-3340 • FAX 301-269-2369
 www.fredericktownelabs.com • info@fredericktownelabs.com

Certificate of Analysis

Acct. No. 9494 - 1-1

Field Record

Site visit performed on: Monday, February 23, 2015 11:50 AM
 by: Richard Snyder State ID No. 0043RS
 Affiliation: Fredericktowne Labs, Inc.
 Property Owner: JKC Quality Construction
 Property Address: 17197 Hardy Road
 Mt. Airy, MD 21771
 Sample Source: Bathroom Sink
 Well No.: HO-95-0327
 Field pH: 5.9
 Total Res. Cl.: <0.1 mg/l

Laboratory Report

Sample Received at laboratory: 2/23/2015 1:03 PM

Bacteriological results:

Total Colif. (/100ml)	E.coli. (/100ml)	Start		End		Method	Analyst
		Date	Time	Date	Time		
<1	<1	02/23/15	14:07	02/24/15	14:39	9223B	JD

Bacteriological analysis of this sample indicates the water is safe for human consumption and meets federal, state and local requirements. Analysis was performed according to the 20th edition of Standard Methods

Inorganic Chemical results:

Parameter	Result Units	MCL	Date of Analysis	Method	Analyst
Nitrate-Nitrogen	5.4 mg/l	10	2/23/2015	300.0	PH
Sand	<2 mg/l	5	2/23/2015	0.065mm Filter	JD
Turbidity	0.4 NTU	10	2/23/2015	180.1	KMW

Reported by: Colleen Mellatt 2/24/15
 Name Date

Fredericktowne Labs, Inc. is a State Certified Water Quality Laboratory
 Maryland Cert. No. 118 Virginia Cert. No. 00444
 MDOT WBE Cert. No.: 91-158

Chain of Custody Form

Fredericktowne Labs, Inc.

3020 Ventrie Ct. P. O. Box 245

Myersville, MD 21773-

(301) 293-3340 / FAX (301) 293-2368

Acct. No.: 9494-1-1

Project: JKC Quality Construction 17197 Hardy Road Mt. Airy, MD 21771	Collected by: <i>Richard J. Snyder</i> Affiliation: FREDERICKTOWNE LABS, INC.
--	---

Sample Description Sample Number	Date of Collection	Time of Collection	Analysis to be Performed	Field Observations	Preservation	Verif. By:
Source: Bathroom Sink Matrix: Drinking Water Grab/Comp: Grab		<i>11:50 A Time</i>		<i>CL - 4.1 PH. 5.9 Temp. 11.4 C</i>		
9494-1-1-1	<i>2/23/15</i>		Bacteria - Colliert 200		Na2S2O3	

Source: Bathroom Sink Matrix: Drinking Water Grab/Comp: Grab						
9494-1-1-2	<i>2/23/15</i>		Nitrate-Nitrogen		4 degrees C	
			Turbidity			

Source: Bathroom Sink Matrix: Drinking Water Grab/Comp: Grab						
9494-1-1-3	<i>2/23/15</i>		Sand		4 degrees c	

If lead or copper are sample collection forms attached?
 Yes No Water last used: _____ (Date) _____ (Time)

Relinquished by: <i>[Signature]</i> <i>2/23/15 1:03p</i>	Received by: <i>[Signature]</i> <i>2/23/15 1:30p</i>
Relinquished by:	Received by:
Relinquished by:	Received by:

Method of Shipment:	load: Yes <input type="checkbox"/> No <input type="checkbox"/> Temp <input type="checkbox"/>	Treatment:
---------------------	--	------------

Note: HOWARD COUNTY U & O
 WEDNESDAY between 4:00 - 6:00 pm. MUST call
 1st call Jamie 301-972-9547 and then call Kevin's cell 240-372-2412 with a time to meet on *Monday* Thursday.
 MUST GET WELL TAG NUMBER & VERIFY SYSTEMS
 Howard County U & O requested via email. 2/17/15 - permit holder is JKC Quality Construction. *Lockbox: 2042*

Well # HO-95-0327

Contractor on site. JS