

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1415 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 98973 Account #: 2425
 Reference: Waldon Woods Company: HTI
 Location: [REDACTED] Requested By: Barry Fisher
 Laurel, MD 20723 Source: Municipal
 Date/ Time Collected: 2/16/2015 1122 Site: Source
 Date/Time Rec'd: 2/16/2015 1405 Treatment: Municipal Chlorination
 Chlorine ppm: Free: 0.32 Total: 0.40 pH: NT
 Collected By: R. Ott 4269RO Well #: N/A

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, P/A	Absent	Total Coliform	Absent	SM18 9223	2/17/2015 / 1000 / CCH
Bacteria, E. coli, P/A	Absent	E. coli	Absent	SM18 9223	2/17/2015 / 1000 / CCH

NOTES

- 1 P/A= Presence or Absence of Coliform Bacteria
- 2 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 3 N/A = Not applicable; NT: Not Tested
- 4 Chlorine level tested on site
- 5 Thio Check Negative

Reason for Test : Client's InformationDate Reported: 2/17/2015