

PUB. SEWER STATUS VERIFIED BY _____

ISSUE DATE: _____

PERMIT

P 536686

APPROVAL DATE: 1/18/2012

A REPAIR

Septic Repair ON-SITE SEWAGE DISPOSAL SYSTEM HOWARD COUNTY HEALTH DEPARTMENT BUREAU OF ENVIRONMENTAL HEALTH

GPS-Yes

J.M.Contracting LLC. IS PERMITTED TO INSTALL ALTER

ADDRESS: 425 Obrecht Road Sykesville, MD 21784 PHONE NUMBER: 443-277-7526

SUBDIVISION: _____ LOT NUMBER: _____

ADDRESS: 11006 Gaither Farm Road PROPERTY OWNER: Daniel and Dawn Balkin

SEPTIC TANK CAPACITY (GALLONS): N/A Trenches 2' Wide

PUMP CHAMBER CAPACITY (GALLONS): _____ Inlet 5'

NUMBER OF BEDROOMS: 4 Bottom 10.5'

SQUARE FEET OF HOUSE: _____

LINEAR FEET OF TRENCH REQUIRED: 150' 2-75' Trenches

TRENCHES:	
LOCATION:	
PURPOSE:	

PLANS APPROVED: B. Baber DATE: 1/13/2012

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS

NEITHER THE HOWARD COUNTY COUNCIL OR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT CALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM

NOT TO SCALE

See As-Built Drawing
On Separate Sheet

ROAD NAME

TRENCH/DRAINFIELD DATA		
WIDTH	INLET	BOTTOM
2'	5'	10.5'
NUMBER OF TRENCHES		2
TOTAL LENGTH		151'
ABSORPTION AREA		529
DISTRIBUTION BOX LEVEL		Levelers
DISTRIBUTION BOX BAFFLE		Yes
DISTRIBUTION BOX PORT		No

SEPTIC TANK DATA ?	
SEPTIC TANK 1 LEVEL	
MANUFACTURER	?
CAPACITY	2000 GAL
SEAM LOC	
TANK LID DEPTH	1'-1.5'
BAFFLES	Yes
BAFFLE FILTER	No
MANHOLE LOC	Front+Rear
6" PORT LOC	None
WATERTIGHT TEST	No
SLOTTED	?
DATE ON LID	No
PUMP/SEPTIC TANK LEVEL	N/A
MANUFACTURER	
CAPACITY	GAL
SEAM LOC	
TANK LID DEPTH	
BAFFLES	
BAFFLE FILTER	
MANHOLE LOC	
6" PORT LOC	
WATERTIGHT TEST	
SLOTTED	
DATE ON LID	

PRE-CONSTRUCTION:

1/13/2012 Install two 75' trenches on contour above holes A and C. Keep trenches 100' from well. Trench locations checked and marked on site, (BB)

INSTALLATION: 1/18/2012 System finished. O.K. to backfill, (BB)

FINAL INSPECTOR B. Baber

DATE OF APPROVAL 1/18/2012

