

PUBLIC SEWER STATUS VERIFIED BY

ISSUE DATE: 6/5/12

# PERMIT

P 537326

APPROVAL DATE: 6/22/12

A REPAIR

## Septic Repair ON-SITE SEWAGE DISPOSAL SYSTEM HOWARD COUNTY HEALTH DEPARTMENT BUREAU OF ENVIRONMENTAL HEALTH

Fogle's Septic IS PERMITTED TO INSTALL  ALTER

ADDRESS: 580 Obrecht Rd. Sykesville, MD 21784 PHONE NUMBER: 410-795-5670

SUBDIVISION: \_\_\_\_\_ LOT NUMBER: 49

ADDRESS: 12222 Carroll Mill Road PROPERTY OWNER: \_\_\_\_\_

SEPTIC TANK CAPACITY (GALLONS): Ex.

PUMP CHAMBER CAPACITY (GALLONS): N/A

NUMBER OF BEDROOMS: 4

SQUARE FEET OF HOUSE: \_\_\_\_\_

LINEAR FEET OF TRENCH REQUIRED: 104LF

*~ Bottom Stone*

TRENCHES:	Trenches to be <u>2</u> feet wide. Inlet <u>3.5-4</u> feet below original grade. Bottom maximum depth <u>10</u> feet below grade. Effective area begins at 6 feet below original grade with <u>6</u> feet of stone below distribution pipe.
LOCATION:	Trenches painted out in field. Run a 46' and 58' trenches on contour across top part of front yard towards ex. drive.
NOTES:	Manhole riser to be added to existing S.T. Existing drywell to be pumped and collapsed. Obs. pipes to be installed at ends of trenches. Homeowner can opt for a 5 bedroom install but a new septic tank will need to be installed (2000g 2 comp.). Trench design will be 3 total (40', 50', and 60' respectively. A layout is required for a 5 bedroom install. Future building permit for bedroom addition may require a percolation certification plan.

*Know*

PLANS APPROVED: K. Wolf DATE: ~~3/26/2012~~

6/19/12

- NOTE: PERMIT VOID AFTER 2 YEARS
- NOTE: CONTRACTOR RESPONSIBLE FOR SCHEDULING A PRE-CONSTRUCTION INSPECTION FOR ALL INSTALLATIONS
- NOTE: WATERTIGHT SEPTIC TANKS REQUIRED
- NOTE: ALL PARTS OF SEPTIC SYSTEM SHALL BE 100 FEET FROM ANY WATER WELL
- NOTE: MANHOLE RISERS REQUIRED ON ALL SEPTIC TANKS AND PUMP CHAMBERS
- NOTE: AN ELECTRICAL PERMIT IS REQUIRED FOR INSTALLATION OF ANY ELECTRICAL COMPONENTS OF THE SYSTEM

**NEITHER THE HOWARD COUNTY COUNCIL OR THE HEALTH DEPARTMENT IS RESPONSIBLE FOR THE SUCCESSFUL OPERATION OF ANY SYSTEM PERMITTEE RESPONSIBLE FOR OBTAINING FINAL APPROVAL ON THIS PERMIT ALL 410-313-1771 FOR INSPECTION OF SEPTIC SYSTEM**

