

APPLICATION

FOR PERCOLATION TESTING AND SITE EVALUATION

TEST DATE(S) _____ TEST TIME _____

@P 522008-D

AGENCY REVIEW: _____

DATE 3/4/05

DO NOT WRITE ABOVE THIS LINE

I HEREBY APPLY FOR THE NECESSARY TESTING/EVALUATION PRIOR TO ISSUANCE OF SEWAGE DISPOSAL SYSTEM PERMIT(S) TO:

CHECK AS NEEDED:

- CONSTRUCT NEW SEPTIC SYSTEM(S)
- REPAIR/ADD TO AN EXISTING SEPTIC SYSTEM
- REPLACE AN EXISTING SEPTIC SYSTEM

CHECK AS NEEDED:

- NEW STRUCTURE(S)
- ADDITION TO AN EXISTING STRUCTURE
- REPLACE AN EXISTING STRUCTURE

CHECK ONE:

- CREATE NEW LOT(S)
- BUILD ON AN EXISTING LOT IN A SUBDIVISION
- BUILD ON AN EXISTING PARCEL OF RECORD

IS THE PROPERTY WITHIN 2500' OF ANY RESERVOIR?

- YES
- NO

THE TYPE OF STRUCTURE IS:

- RESIDENTIAL WITH _____ PROPOSED BEDROOMS IN THE COMPLETED STRUCTURE (NOTE *UNKNOWN* IF APPROPRIATE)
- COMMERCIAL (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/ CUSTOMERS ON ACCOMPANYING PLAN)
- INSTITUTIONAL/GOVERNMENT (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/USERS ON ACCOMPANYING PLAN)

PROPERTY OWNER(S) C. EDGAR PUGH, JR.

DAYTIME PHONE _____ CELL _____ FAX _____

MAILING ADDRESS 2289 MCKENDREE ROAD WEST FRIENDSHIP MO 21794
STREET CITY/TOWN STATE ZIP

APPLICANT BENCHMARK ENGINEERING, INC.

DAYTIME PHONE 410-465-6105 CELL _____ FAX 410-465-6644

MAILING ADDRESS 8480 BALT. NATIONAL PIKE, SUITE 418 ELLCOTT CITY MO 21043
STREET CITY/TOWN STATE ZIP

APPLICANT'S ROLE: DEVELOPER BUILDER BUYER RELATIVE/FRIEND REALTOR CONSULTANT

PROPERTY LOCATION
SUBDIVISION/PROPERTY NAME MCKENDREE VIEW LOT NO. 4

PROPERTY ADDRESS 2289 MCKENDREE ROAD WEST FRIENDSHIP MO 21794
STREET TOWN/POST OFFICE

TAX MAP PAGE(S) 41 & 42 GRID 1,6,7 & 12 PARCEL(S) 54 PROPOSED LOT SIZE 1.0 AC

AS APPLICANT, I UNDERSTAND THE FOLLOWING: THE SYSTEM INSTALLED SUBSEQUENT TO THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC SEWERAGE IS AVAILABLE. THIS APPLICATION IS COMPLETE WHEN ALL APPLICABLE FEES AND A SUITABLE SITE PLAN HAVE BEEN RECEIVED. I ACCEPT THE RESPONSIBILITY FOR COMPLIANCE WITH ALL M.O.S.H.A. AND "MISS UTILITY" REQUIREMENTS. APPROVAL IS BASED UPON SATISFACTORY REVIEW OF A PERC CERTIFICATION PLAN.

TEST RESULTS WILL BE MAILED TO APPLICANT. Donald Mason
SIGNATURE OF APPLICANT


HOWARD COUNTY HEALTH DEPARTMENT, BUREAU OF ENVIRONMENTAL HEALTH, WELL AND SEPTIC PROGRAM
3525-H ELLICOTT MILLS DRIVE, ELLICOTT CITY, MARYLAND 21043-4544 (410) 313-1771 FAX (410) 313-2648
TDD (410) 313-2323 TOLL FREE 1-877-4MD-DHMH

ODONNELL PROPERTY
PLAT NO. 12285
ZONED-RC

RCCEL 'A'

Now Plat 12286

Signed
PC
5/26/65



A/P 19


Brown C	1'
Orange/Brown CL	2 1/2'
Brown/Yellow SCL	5'
Yellow/Brown Sl w/ 15% cobbles	10'
Yellow/Brown S	14'

P-15

Black/Brown L	1'
Yellow/Brown heavy CL	4'
Yellow/Red SCL w/ 10% cobbles	5 1/2'
Red/Orange Sl	11'
Yellow/Brown SL	15'

P-16

Brown L	1'
Yellow/Brown heavy CL	4'
Red/Orange CL	7'
Yellow/Red Sl w/ 10% cobbles	12'
Yellow/Brown Sl	13 1/2'



P-17

Brown L	1'
Yellow/Brown heavy CL	4 1/2'
Red/Orange SCL	6'
Brown/Red Yellow SL	10'
Yellow/Brown SL	12 1/2'


DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2nd INCH	P/F/H
3/30/05	P-19	6' / 14'	7:42	7:45	7:49	4mins	P
	P-15	6 1/2' / 15'	7:50	7:55	8:05	10mins	P
	P-16	8' / 13 1/2'	8:18	8:22	8:26	4mins	P
	P-17	7 1/2' / 12 1/2'	8:12	8:15	8:21	6mins	P

REMARKS Holes dug to plan, bottom of ^{holes} lot 4 moved uphill and field located.

SANITARIAN KB/SF BACKHOE Hatfield (Domic) OTHERS

TEST HOLES USED IN SDA _____ AVG. PERC TIME _____ SQ. FT/BR _____

TRENCH WIDTH _____ INLET DEPTH _____ MAX. BOT DEPTH _____ EFFECTIVE S/W _____



APPLICATION

FOR PERCOLATION TESTING AND SITE EVALUATION

TEST DATE(S) _____ TEST TIME _____

@P 522008-D

AGENCY REVIEW: _____

DATE 3/4/05

DO NOT WRITE ABOVE THIS LINE

I HEREBY APPLY FOR THE NECESSARY TESTING/EVALUATION PRIOR TO ISSUANCE OF SEWAGE DISPOSAL SYSTEM PERMIT(S) TO:

CHECK AS NEEDED:

- CONSTRUCT NEW SEPTIC SYSTEM(S)
- REPAIR/ADD TO AN EXISTING SEPTIC SYSTEM
- REPLACE AN EXISTING SEPTIC SYSTEM

CHECK AS NEEDED:

- NEW STRUCTURE(S)
- ADDITION TO AN EXISTING STRUCTURE
- REPLACE AN EXISTING STRUCTURE

CHECK ONE:

- CREATE NEW LOT(S)
- BUILD ON AN EXISTING LOT IN A SUBDIVISION
- BUILD ON AN EXISTING PARCEL OF RECORD

IS THE PROPERTY WITHIN 2500' OF ANY RESERVOIR?

- YES
- NO

THE TYPE OF STRUCTURE IS:

- RESIDENTIAL WITH _____ PROPOSED BEDROOMS IN THE COMPLETED STRUCTURE (NOTE *UNKNOWN* IF APPROPRIATE)
- COMMERCIAL (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/ CUSTOMERS ON ACCOMPANYING PLAN)
- INSTITUTIONAL/GOVERNMENT (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/USERS ON ACCOMPANYING PLAN)

PROPERTY OWNER(S) C. EDGAR PUGH, JR

DAYTIME PHONE _____ CELL _____ FAX _____

MAILING ADDRESS 2289 MCKENDREE ROAD WEST FRIENDSHIP MD 21794
STREET CITY/TOWN STATE ZIP

APPLICANT BENCHMARK ENGINEERING, INC.

DAYTIME PHONE 410-465-6105 CELL _____ FAX 410-465-6644

MAILING ADDRESS 8480 BALT. NATIONAL PIKE, SUITE 418 ELLICOTT CITY MD 21043
STREET CITY/TOWN STATE ZIP

APPLICANT'S ROLE: DEVELOPER BUILDER BUYER RELATIVE/FRIEND REALTOR CONSULTANT

PROPERTY LOCATION
SUBDIVISION/PROPERTY NAME MCKENDREE VIEW LOT NO. 4

PROPERTY ADDRESS 2289 MCKENDREE ROAD WEST FRIENDSHIP MD 21794
STREET TOWN/POST OFFICE

TAX MAP PAGE(S) 41 & 42 GRID 1,6,7 & 12 PARCEL(S) 54 PROPOSED LOT SIZE 1.0 AC

AS APPLICANT, I UNDERSTAND THE FOLLOWING: THE SYSTEM INSTALLED SUBSEQUENT TO THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC SEWERAGE IS AVAILABLE. THIS APPLICATION IS COMPLETE WHEN ALL APPLICABLE FEES AND A SUITABLE SITE PLAN HAVE BEEN RECEIVED. I ACCEPT THE RESPONSIBILITY FOR COMPLIANCE WITH ALL M.O.S.H.A. AND "MISS UTILITY" REQUIREMENTS. APPROVAL IS BASED UPON SATISFACTORY REVIEW OF A PERC CERTIFICATION PLAN.

TEST RESULTS WILL BE MAILED TO APPLICANT.

Donald Mason
SIGNATURE OF APPLICANT

HOWARD COUNTY HEALTH DEPARTMENT, BUREAU OF ENVIRONMENTAL HEALTH, WELL AND SEPTIC PROGRAM
3525-H ELLICOTT MILLS DRIVE, ELLICOTT CITY, MARYLAND 21043-4544 (410) 313-1771 FAX (410) 313-2648
TDD (410) 313-2323 TOLL FREE 1-877-4MD-DHMH

CHARLES L. OSTERMAN
438 / 209

ED M. HOUGH
PROPERTY
AT NO. 4168

Handwritten: Copy Peter Cost Signed 7/6/06
SHEET 6 of 50 pages

PRIVATELY OWNED
RESERVATION PARCEL
3.51 AC
HOWARD COUNTY HOLDERS
BASEMENT DWELLING
EX. 2289

MEADOW TRAIL LANE
227.06'

LOT 7
16,542 SF

LOT 6
43,809 SF

LOT 5
44,454 SF

LOT 3
40,000 SF

LOT 4
51,998 SF

O.A. OWNED
NON-BUILDABLE
RESERVATION
PARCEL C
1.56 AC ±
HOWARD COUNTY

RETAINED FOREST
LIMIT 1.0 ACRES

O'DONNELL PROPERTY
19285





APPLICATION

FOR PERCOLATION TESTING AND SITE EVALUATION

TEST DATE(S) _____ TEST TIME _____

AP 522008-E

AGENCY REVIEW: _____

DATE 3/4/05

DO NOT WRITE ABOVE THIS LINE

I HEREBY APPLY FOR THE NECESSARY TESTING/EVALUATION PRIOR TO ISSUANCE OF SEWAGE DISPOSAL SYSTEM PERMIT(S) TO:

CHECK AS NEEDED:

- CONSTRUCT NEW SEPTIC SYSTEM(S)
- REPAIR/ADD TO AN EXISTING SEPTIC SYSTEM
- REPLACE AN EXISTING SEPTIC SYSTEM

CHECK AS NEEDED:

- NEW STRUCTURE(S)
- ADDITION TO AN EXISTING STRUCTURE
- REPLACE AN EXISTING STRUCTURE

CHECK ONE:

- CREATE NEW LOT(S)
- BUILD ON AN EXISTING LOT IN A SUBDIVISION
- BUILD ON AN EXISTING PARCEL OF RECORD

IS THE PROPERTY WITHIN 2500' OF ANY RESERVOIR?

- YES
- NO

THE TYPE OF STRUCTURE IS:

- RESIDENTIAL WITH _____ PROPOSED BEDROOMS IN THE COMPLETED STRUCTURE (NOTE *UNKNOWN* IF APPROPRIATE)
- COMMERCIAL (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/ CUSTOMERS ON ACCOMPANYING PLAN)
- INSTITUTIONAL/GOVERNMENT (PROVIDE DETAIL OF NUMBERS AND TYPES OF EMPLOYEES/USERS ON ACCOMPANYING PLAN)

PROPERTY OWNER(S) C. EDGAR PUGH, JR

DAYTIME PHONE _____ CELL _____ FAX _____

MAILING ADDRESS 2289 MCKENDREE ROAD WEST FRIENDSHIP MD 21794
STREET CITY/TOWN STATE ZIP

APPLICANT BENCHMARK ENGINEERING, INC.

DAYTIME PHONE 410-465-6105 CELL _____ FAX 410-465-6044

MAILING ADDRESS 8480 BALT. NATIONAL PIKE, SUITE 418 ELLICOTT CITY MD 21043
STREET CITY/TOWN STATE ZIP

APPLICANT'S ROLE: DEVELOPER BUILDER BUYER RELATIVE/FRIEND REALTOR CONSULTANT

PROPERTY LOCATION
SUBDIVISION/PROPERTY NAME MCKENDREE VIEW LOT NO. 5

PROPERTY ADDRESS 2289 MCKENDREE ROAD WEST FRIENDSHIP MD 21794
STREET TOWN/POST OFFICE


TAX MAP PAGE(S) 41 §42 GRID 1,6,7&12 PARCEL(S) 54 PROPOSED LOT SIZE 1.0 AC

AS APPLICANT, I UNDERSTAND THE FOLLOWING: THE SYSTEM INSTALLED SUBSEQUENT TO THIS APPLICATION IS ACCEPTABLE ONLY UNTIL PUBLIC SEWERAGE IS AVAILABLE. THIS APPLICATION IS COMPLETE WHEN ALL APPLICABLE FEES AND A SUITABLE SITE PLAN HAVE BEEN RECEIVED. I ACCEPT THE RESPONSIBILITY FOR COMPLIANCE WITH ALL M.O.S.H.A. AND "MISS UTILITY" REQUIREMENTS. APPROVAL IS BASED UPON SATISFACTORY REVIEW OF A PERC CERTIFICATION PLAN.


TEST RESULTS WILL BE MAILED TO APPLICANT. Donald Mason
SIGNATURE OF APPLICANT

HOWARD COUNTY HEALTH DEPARTMENT, BUREAU OF ENVIRONMENTAL HEALTH, WELL AND SEPTIC PROGRAM
3525-H ELLICOTT MILLS DRIVE, ELLICOTT CITY, MARYLAND 21043-4544 (410) 313-1771 FAX (410) 313-2648
TDD (410) 313-2323 TOLL FREE 1-877-4MD-DHMH



A/P P-21




P-18




P-20



P-23



P-22



DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2nd INCH	P/F/H
3/3/05	P-21	5' / 13'	8:29	8:30	8:32	2min	P
	P-18	6 1/2' / 13'	8:36	8:39	8:44	5min	P
	P-20	6 1/2' / 13'	8:50	8:53	8:59	6min	P
	P-23	7.5' / 13'	9:20	9:29	9:47	12	P
	P-22	6 1/2' / 13'	9:25	9:27	9:29	2min	P

REMARKS: ^{hole #20} Bottom of lot 5 moved up hill due to grade. Field located
 SANITARIAN KB/SF BACKHOE Hatfield (Donnie) OTHERS _____
 TEST HOLES USED IN SDA _____ AVG. PERC TIME _____ SQ. FT/BR _____
 TRENCH WIDTH _____ INLET DEPTH _____ MAX. BOT DEPTH _____ EFFECTIVE SW _____