



Howard County  
Health Department

**BUREAU OF ENVIRONMENTAL  
HEALTH**

7178 Columbia Gateway Drive,  
Columbia, MD 21046  
Phone (410) 313-2640 Fax (410) 313-2648

TDD (410) 313-2323  
Toll Free 1-866-313-6300  
Website: [www.hchealth.org](http://www.hchealth.org)

**FAX**

To: Attention: Brian Benchmark Engineering, Inc.	From: Dana Bernard
Fax: (410) 465-6644	Pages: 2
Phone: (410) 465-6105	Date: 3/16/2009
Re: Pride's Crossing	cc:

**Comments:**

If you have any questions or correspondence, I can be reached at the above address or by telephone at (410) 313-2775.

Thanks,  
*Dana L. Bernard*  
Dana L. Bernard, Sanitarian  
Bureau of Environmental Health  
Well and Septic Program  
Phone (410) 313-2775  
Fax (410) 313-2648  
E-mail: [DBernard@howardcountymd.gov](mailto:DBernard@howardcountymd.gov)

**IMPORTANT WARNING:** This message is intended for the use of the person or entity to which it is addressed and may contain information that is privileged and confidential, the disclosure of which is governed by applicable law. If the reader of this message is not the intended recipient, or the employee or agent responsible to deliver it to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this information is **STRICTLY PROHIBITED**. If you have received this message in error, please notify the sender immediately and arrange for the return or destruction of these documents.



7178 Columbia Gateway Drive, Columbia MD 21046  
(410) 313-2640 Fax (410) 313-2648  
TDD (410) 313-2323 Toll Free 1-866-313-6300  
Website: [www.hchealth.org](http://www.hchealth.org)

Peter L. Beilenson, M.D., M.P.H., Health Officer

---

MEMORANDUM

TO: Brian, Benchmark Engineering, Inc.

FROM: Dana Bernard, Well and Septic Program  
Development Coordination Section

RE: Carroll Mill Road (Pride's Crossing Lot #1),  
Ellicott City, Maryland 21742  
Tax Map: 23, Parcel: 79

DATE: March 16, 2009

---

The following comments apply to the plan prepared Benchmark Engineering, Inc.  
Applicant is advised to revise and resubmit prior to signature.

- Existing well tag # must be noted on lot #2. Two wells exist on lot #2 and only one is shown on Perc Certification Plan.
- Legend must include symbols for existing wells and proposed wells.
- Symbol in legend for passed test hole must not have any numbers next to it other than the date test hole was dug.

**In the general notes:**

- **Note #3 is stated incorrectly.** State as follows: "Topography shown must be field run or verified by (State the name of surveyor or engineer) on (State the date)." **Must be updated.**
- **Note #4 is stated incorrectly.** State as follows: "Existing wells and / or sewerage easements within 100 feet of the property have been shown from the best available information. "
- **Note # 6 is stated incorrectly.** State as follows: "All wells shall be drilled prior to final plat recordation. It is the developer's responsibility to schedule the well drilling prior to final plat submission. It will not be considered "Government Delay" if the well drilling holds-up the health department signature of the record plat.

If you have any questions or correspondence, I can be reached at the above address or by telephone at (410) 313-2775.

Sincerely,

Dana L. Bernard, Sanitarian  
Bureau of Environmental Health, Well and Septic Program  
Phone (410) 313-2775  
Fax (410) 313-2648  
E-mail: [DBernard@howardcountymd.gov](mailto:DBernard@howardcountymd.gov)