

# HARR WELL DRILLING

12047 FALLS ROAD  
COCKEYSVILLE, MD 21030  
410-252-4588

## HOWARD COUNTY YIELD TEST REPORT

Date Test Performed: 05-14-09  
Address: 14713 McCann Farm Road  
Owner Name: Aizad Dasti  
Well Depth:

Permit Number: HO- 94-3330  
Subdivision: McCann Prop. Lot 4  
Election District:  
Static Water Level:

Time	Water Level	PSI Existing Pump	Pumping Rate Seconds to fill 1 gallon bucket	Calculated Flow-Gallons Per Minute
1100		25 psi	5 sec	12.00
1115		25	5	12.00
1130		25	5	12.00
1145		25	5	12.00
1200		25	5	12.00
1215		25	5	12.00
1230		25	5	12.00
1245		25	5	12.00
1300		25	5	12.00
1315		25	5	12.00
1330		25	5	12.00
1345		25	5	12.00
1400		25	5	12.00