

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #:	66867	Account #:	10157
Reference:	Audrey Wong	Company:	CASH ACCOUNT
Location:	11945 Simpson Road Clarksville, MD 21029	Requested By:	Audrey Wong
Date/ Time Collected:	3/6/2008 1010	Source:	Well Water
Date/Time Rec'd:	3/6/2008 1234	Site:	Kitchen Sink Tap
Chlorine ppm:	Free: ND Total: ND	Treatment:	Sediment Filter
Collected By:	J.Yeager 6176JY	pH:	5.5
		Well #:	No Tag

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	>200.5	MPN/ 100 ml	<1.0	SM18 9223 B.	3/7/2008 / 0815 / AD/BD
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223 B.	3/7/2008 / 0815 / AD/BD

NOTES

- 1 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 2 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 3 ND:None Detected
- 4 Visual well check: Pit
- 5 pH tested on-site

Reason for Test : HOHD/Rental

Date Reported: 3/7/2008