

FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Fancytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554 FAX (410) 848-0298

REPORT OF ANALYSIS

Laboratory ID #: 74722 Account #: 2440
 Reference: Old Tyme Liquors Company: Hydro-Terra Group
 Location: 13589 Triadelphia Road Requested By: Jeff Lindaw
 Glenelg, MD 21737 Source: Well Water
 Date/ Time Collected: 3/31/2010 1050 Site: Basement Spigot
 Date/Time Rec'd: 3/31/2010 1300 Treatment: Carbon Unit*
 Chlorine ppm: Free: ND Total: ND pH: 7.4
 Collected By: J. Lindaw 0249JL Well #: HO-95-1140

PARAMETERS	RESULTS	UNITS	REFERENCE	METHOD	DATE/TIME/ANALYST
Bacteria, Coliform, Total, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	4/1/2010 / 0845 / KME
Bacteria, E. coli, MPN	<1.0	MPN/ 100 ml	<1.0	SM18 9223	4/1/2010 / 0845 / KME
Nitrate	<1.0	mg/L	10	601	3/31/2010 / 1530 / CCH
Chloride	<5.0	mg/L	250	SM18 4500-Cl-B	3/31/2010 / 1805 / CCH
Sand	NS	mg/L	5	Visual/Gravimet	4/1/2010 / 0817 / KME
Turbidity	5.37	NTU	<10	SM18 2130B	3/31/2010 / 1315 / KME

NOTES

- 1 mg/l. = milligrams per liter (also, parts per million)
- 2 MPN/ 100 ml = Most Probable Number [of viable bacteria] per 100 ml of sample.
- 3 NS = None Seen (NS indicates less than 5 mg/L)
- 4 NTU = Nephelometric Turbidity Units
- 5 pH & chlorine level tested in lab
- 6 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 7 ND = None Detected
- 8 Sample collected by client, analyzed as received
- 9 *Sample collected prior to treatment

Reason for Test : Certificate of Potability for HC

Date Reported: 4/1/2010