

**CERTIFICATE OF ANALYSIS**

**Requester:**  
Lockxley Bailey  
5711 Trotter Road  
Clarksville, Maryland 21029

**S/O Number:** 64266  
**Report Date:** July 11, 2007

**Trace Laboratories, Inc.  
Maryland**

5 North Park Drive  
Hunt Valley, MD 21030  
Telephone: 410/252-7742  
Telephone: 410/584-9099  
Fax: 410/584-9117  
Email: tracelab@connex.net  
www.tracelabs.com

Maryland State Certified  
Water Quality Laboratory  
No. 318

**ISO 9001:2000**



PERRY JOHNSON  
REGISTRARS, INC.

Cert No. C2005-01504

**Property Sampled:** 5711 Trotter Road - Retest

**County:** Howard  
**Subdivision:** N/A  
**Lot #:** N/A  
**Tax Map #:** 35  
**Parcel #:** 198

**Date/Time Collected:** July 10, 2007 at 12:15 pm  
**Date/Time Received:** July 10, 2007 at 3:00 pm

**Sample Location:** Powder Room Tap  
**Sampler ID:** 6308KW  
**Samples Iced:** Yes  
**Residual Cl<sub>2</sub> <0.1 mg/L:** Yes

**Well Tag Number:** HO-95-1049  
**Well Condition:** 2-Piece Cap  
Satisfactory

**Water Conditioning/Treatment:** Neutralizer, Softener

PARAMETER	RESULT	METHOD	MCL	
Total Coliform	Absent	SM 9223B	Absent	Pass
E.coli	Absent	SM 9223B	Absent	Pass

*Allison R. Milburn*  
Allison R. Milburn  
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

**CERTIFICATE OF ANALYSIS**

Trace Laboratories, Inc.  
Maryland

5 North Park Drive  
Hunt Valley, MD 21030  
Telephone: 410/252-7742  
Telephone: 410/584-9099  
Fax: 410/584-9117  
Email: tracelab@connxt.net  
www.tracelabs.com

Maryland State Certified  
Water Quality Laboratory  
No. 318

ISO 9001:2000



Cert No. C2005-01504

**Requester:**  
Lockxley Bailey  
5711 Trotter Road  
Clarksville, Maryland 21029

**S/O Number:** 63819  
**Report Date:** June 11, 2007

**Property Sampled:** 5711 Trotter Road - New Well

**County:** Howard  
**Subdivision:** N/A  
**Lot #:** N/A  
**Tax Map #:** 35  
**Parcel #:** 198

**Date/Time Collected:** June 8, 2007 at 1:30 pm  
**Date/Time Received:** June 8, 2007 at 2:30 pm

**Sample Location:** Powder Room Tap & Pressure Tank  
**Sampler ID:** 6308KW  
**Samples Iced:** Yes  
**Residual Cl<sub>2</sub> <0.1 mg/L:** Yes

**Well Tag Number:** HO-95-1049  
**Well Condition:** 2-Piece Cap  
Satisfactory

**Water Conditioning/Treatment:** Neutralizer, Softener

PARAMETER	RESULT	METHOD	MCL/*SMCL	
Nitrate	1.3 mg/L as N	SM 4500D	10 mg/L as N	Pass
Turbidity (Raw)	3.0 NTU	EPA 180.1	10 NTU	Pass
Turbidity (Treated)	2.0 NTU	EPA 180.1	10 NTU	Pass
pH (Raw)	5.6 Units	EPA 150.1	*6.5-8.5 Units	***
pH (Treated)	5.6 Units	EPA 150.1	*6.5-8.5 Units	***
Sand	Negative		Negative	
Total Coliform	PRESENT	SM 9223B	Absent	FAIL
E.coli	Absent	SM 9223B	Absent	

*Allison R. Milburn*  
Allison R. Milburn  
Manager-Drinking Water Testing

MCL=Maximum Contamination Level

\*SMCL=Secondary Maximum Contamination Level

\*\*\*A non-enforceable parameter that may cause cosmetic effects or aesthetic effects (such as taste, color or odor) in drinking water.