

HARR WELL DRILLING

12047 FALLS ROAD
COCKEYSVILLE, MD 21030
410-252-4588

HOWARD COUNTY WELL YIELD TEST REPORT

Date Test Performed: 04-16-10 Permit Number: HO
Address: 12301 Howard Lodge Drive Subdivision:
Owner: Linda Wood Election District:
Well Depth: Static Water Level: 18 Ft

THIS IS A HAND DUG WELL:

Time	Water Level	PSI Existing Pump	Pumping Rate Seconds to fill 5 Gallon bucket	Calculated Flow-Gallons Per Minute
0830	18 ft	19 psi	34 sec	8.82
0845	20	38	22	13.63
0900	21	38	21	14.28
0915	22	38	21	14.28
0930	23	38	21	14.28
0945	23	38	21	14.28
1000	23	38	21	14.28
1015	23	38	21	14.28
1030	23	38	21	14.28
1045	23	38	21	14.28
1100	23	38	21	14.28
1115	23	38	21	14.28
1130	23	38	21	14.28