

12107 Mayapple Trail  
Marriottsville, MD 21104  
Phone (410) 442-0000  
Fax (410) 442-5765  
MHIC No. 16414



WAYNE COSSENTINO  
President

June 13, 2006

Mr. Michael Davis  
Bureau of Environmental Health  
7178 Columbia Gateway Drive  
Columbia, MD 21046

Dear Mike:

SUBJECT: 12107 MAYAPPLE TRAIL, MARRIOTTSVILLE, MD 21104

I want to thank you for all your efforts in reference to my septic issues. At this time, however, I have decided to eliminate the sink for the Garage, thus eliminating any further septic issues.

Please forward my permit to the next department for processing.

Sincerely,

A handwritten signature in cursive script that reads "Wayne Cossentino".

Wayne Cossentino



Howard County  
Health Department

Bureau of Environmental Health  
7178 Columbia Gateway Drive, Columbia MD 21046  
(410) 313-2640 Fax (410) 313-2648  
TDD (410) 313-2323 Toll Free 1-866-313-6300  
website: [www.hchealth.org](http://www.hchealth.org)

Penny E. Borenstein, M.D., M.P.H., Health Officer

June 12, 2006

Mr. Wayne Cossentino  
12107 Mayapple Drive  
Marriottsville, MD 21104


Re: 12107 Mayapple Drive  
Marriottsville, MD 21104

Dear Sir:

The Department of Health has reviewed your proposal connect the proposed garage to the existing septic system by installing a 1500 gallon septic tank and 1000 gallon pump chamber to accommodate a wash sink and hose bib in the proposed garage. In order to proceed with the project apply for an upgrade septic system permit and include a copy of a site plan in an engineers scale that illustrates the location of the house, garage, driveway, well, septic system, sewage disposal easement and the proposed connection. The plan must also include invert elevations for the proposed upgrades to the septic system, pump sizing calculations, float elevations and existing contour with any proposed grading for the garage.

Please be advised that I recommend the proposed force main is not connected to the septic tank. Pumping wastewater from a 1000 gallon pump chamber into the septic tank may flush solids out of the tank and into the drainfields. It would be preferable to pump a smaller volume into a surge box or into the existing distribution box.

Sincerely,

  
Michael J. Davis, R.S.  
Director, Well & Septic Program

MJD

*File copy*