

AP 5210184

206  
 1' Bm SiCL  
 Bm gr  
 SiL  
 2' Yell Bm  
 VFSL  
 W/saprolite

207  
 6" Bm L  
 Bm SiCL  
 gr  
 1.5' Yell Bm  
 SiL gr  
 3.5' Yell Bm  
 FSL  
 saprolite

210  
 8" Bm L  
 Yell Bm  
 SiL gr  
 3' Yell Bm  
 FSL  
 Saprolite

Holes dug Per Plan  
 Shown on Back side

208  
 8" Bm L  
 Bm  
 gr SiL  
 4' Yell Bm  
 FSL  
 Saprolite

209  
 8" Bm L  
 Bm  
 gr SiCL  
 2.5' Yell Bm  
 FSL  
 Saprolite

212  
 6" Bm L  
 Bm  
 gr SiCL  
 2.5' Yell Bm  
 SiL  
 3.5' Yell Bm  
 FSL  
 Saprolite

DATE	TEST #	DEPTH	START	BREAK 1" DROP	STOP 2" DROP	TIME OF 2ND INCH	P/F/H
3/14/07	206	4' / 13'	9:31	9:33	9:39	6	P
	207	4' / 11.5'	9:38	9:42	9:50	8	P
	210	4' / 11'	9:41	9:52	10:00	8	P
	209	4' / 12'	10:04	10:08	10:15	7	P
	212	4' / 13'	10:05	10:12	10:22	10	P
	208	VISUAL					P

REMARKS

SANITARIAN AT BACKHOE Justin (level tank) OTHERS Jeremy Rutter  
 TEST HOLES USED IN SDA \_\_\_\_\_ AVG. PERC TIME \_\_\_\_\_ SQ. FT/BR \_\_\_\_\_  
 TRENCH WIDTH \_\_\_\_\_ INLET DEPTH \_\_\_\_\_ MAX. BOT DEPTH \_\_\_\_\_ EFFECTIVE SW \_\_\_\_\_