

# HOWARD COUNTY HEALTH DEPARTMENT

JOYCE M. BOYD, M.D., M.P.H.  
COUNTY HEALTH OFFICER



Bureau of Environmental Health  
3525 Ellicott Mills Drive  
Ellicott City, Maryland 21043

Director - 461-9956  
Water & Sewerage, Permits - 461-9933  
Community Environmental Health - 461-9944  
Technical Services - 461-9955

March 2, 1983

Mr. Donald Proia  
13630 Nichols Drive  
Clarksville, Maryland 21209

RE: Building Permit Application  
Number: 16705  
13630 Nichols Drive  
Lot 1 Clifton Link Property

Dear Mr. Proia:

This is to advise you that this department requests additional capacity be added to the existing septic system prior to a recommendation of approval for the above referenced construction permit. The system installed was for a three bedroom home and is not sized for the wastewater demand that could be generated from the expansion you have proposed.

The application fee for a septic repair permit is \$10.00 and is obtained from this office. The extent of repair required will be determined when the ground and system is opened up for inspection.

If you have any questions relative to this matter, please call me at 461-9933.

Respectfully,

A handwritten signature in cursive script that reads "Craig Williams".

Craig Williams, Director  
Water and Sewerage Program

CW:JR

cc: Avis Corbin