

14645 Mustang Path - Glenwood Estates - Lot 26

FILE INQUIRY NOTES

Scan w/ file
for 14684 Mustang Path
Glenwood Estates Lot 14
P 514982-C

DATE	RESULTS OF REVIEW FOR FILE
7/14/07	<p>Walk thru BP for 14645 Mustang Path for 2 sunroom - No perc-cert on file. Did site visit afternoon of 7/13/07 - Auger (A) confirmed good soils. Also noticed that adjacent wells (opposite side of street) are located and were approved in locations possibly < 100' from - (14676) the originally proposed SDA. Also at least 1 well (14684) is directly downslope of this homes septic system - unsure of exact distance. Potentially impacted addresses (known) are ~ 14645 Mustang Path, ^{septic} 14676 Mustang Path 14684 Mustang Path (wells) Also looks like possible impacts at 14676 14653 uphill of 14692 and possibly < 100' of separation - See preliminary plan approved in Glenwood Estates file for approved locations of wells/septics. These issues need to be addressed at the time of Septic Repair, Well replacement, perc, Bedroom or other major additions. Perc Cert Requirement was waived in this circumstance due to minor nature of the Building Permit. No opportunity for improvement @ this time</p> <p>* Situation needs to be addressed. * <i>Jehif A.</i> <i>gr</i></p> <p>* Please Scan *</p>